

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

## **INSPECTION REPORT**

| Date of Inspection:                 | Jan 13, 2022  | Inspection Result:    | PASSED           |
|-------------------------------------|---|-----------------------|------------------|
| Permit Number:<br>Property Address: | B-21-0704<br>401 VALLEY AVE NE                                  | ;                     |                  |
| Contractor:                         | MERIDIAN POINTE APAF<br>981660826                               | RTMENTS LLC PO BOX 66 | 6826 SEATTLE, WA |
| To construct:                       | INTERIOR UNIT BLDG RI<br>APARTMENTS/BLDG E<br>UNITS 104/204/304 | enovation ~ Meridia   | N POINTE         |
|                                     | BLDG ONLY   |                       |                  |

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** final approved

## Corrections:

- 1 1; provide fire final inspection approval prior to building final inspection.
  - 2 ; provide refrigerator/freezer per ICC A117.1 section 804.5.6 in unit 104.(accessible unit)
  - 3 ; City approved plans not on-site at time of inspection.

Sincerely,

Gary Webster Building Inspector GWebster@PuyallupWA.gov (253) 841-5590



City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org