



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Comment Notice

Permit Application # E-21-0440

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Engineering Civil Review (Reviewed By: Mark Higginson, (253)841-5559, MHigginson@PuyallupWA.gov)

- ◆ Locate sewer and GI 10-ft min from Bldg[Plans; Sht S2]
- ◆ Provide acknowledgement from Williams Gas for sewer alignment through their gas easement.
- ◆ Submit Engineering Cost Estimate Worksheet (City form) for review prior to permit issuance.
- ◆ Sewer line [Plans; Sht S2]
- ◆ Min. 10-ft straight pipe on inlet side of GI (90-deg to inlet) See CS 402.3 [Plans; Sht S2]
- ◆ Callout Sample Tee per CS Detail 04.06.01 [Plans; Sht S2]
- ◆ \$52,710.00

To resubmit, you must address all comments and complete the [resubmittal form](#). Please note, partial resubmittals will be deemed incomplete and returned.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov