



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Comment Notice

Permit Application # B-21-0994

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Engineering Review (Reviewed By: Yianni Charitou, (253)435-3612, YCharitou@PuyallupWA.gov)

- ◆ Revise the site plan to depict the new or existing side sewer connection(s) from the public right-of-way to the building and the location of any sewer cleanout(s). The City does not maintain side sewer records on private property.
- ◆ If applicable, revise the site plan to depict the new or existing stormwater connection(s) from the public right-of-way to the building or any onsite stormwater system(s). The City does not maintain stormwater records on private property.
- ◆ Revise the site plan to depict the new or existing potable water connection(s) from the public right-of-way to the building and the location of the water meter box(es). If applicable, depict the location of any proposed or existing backflow prevention devices. The City does not maintain water service records on private property.

To resubmit, you must address all comments and complete the [resubmittal form](#). Please note, partial resubmittals will be deemed incomplete and returned.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov