



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 20, 2021

Inspection Result: **PARTIAL PASS**

Permit Number: E-21-0066

Property Address: 3303 8TH AVE SE ;

Contractor: RW SCOTT CONSTRUCTION CO. <NO STREET ADDRESS> AUBURN,
WA 98001

To construct: SEWER EXTENSION

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: RW Scott had PCS TV the sewer main. PCS hired Drain Pro to jet the line. Drain Pro was unable to jet the entire line due to a short jet hose. PCS TV'ed the main and there were two bellies south of MH#3 that need to be brought back into spec and multiple areas north of the same manhole that need to be brought into spec.

Corrections:

Sincerely,

Jason Little



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Engineering Tech IV
JLittle@PuyallupWA.gov
(253) 435-3636