



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 05, 2022

Inspection Result: PARTIAL PASS

Permit Number: E-21-0066

Property Address: 3303 8TH AVE SE ;

Contractor: RW SCOTT CONSTRUCTION CO. <NO STREET ADDRESS> AUBURN,
WA 98001

To construct: SEWER EXTENSION

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: No civil work and no communication as to when they will be back on site.

Corrections:

Sincerely,

Jason Little
Engineering Tech IV
JLittle@PuyallupWA.gov
(253) 435-3636



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org