



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 12, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** E-21-0066

**Property Address:** 3303 8TH AVE SE ;

**Contractor:** RW SCOTT CONSTRUCTION CO. <NO STREET ADDRESS> AUBURN,  
WA 98001

**To construct:** SEWER EXTENSION

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** I spoke with RW Scott. They have not begun the sag repair due to dewatering issues. The pump is back up and running, ground water down to 7', they plan to begin the repairs next week.

**Corrections:**

Sincerely,

Jason Little  
Engineering Tech IV  
JLittle@PuyallupWA.gov



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

(253) 435-3636