



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 17, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** E-21-0066

**Property Address:** 3303 8TH AVE SE ;

**Contractor:** RW SCOTT CONSTRUCTION CO. <NO STREET ADDRESS> AUBURN,  
WA 98001

**To construct:** SEWER EXTENSION

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** RW Scott dug up the north side of ssmh#2. the pipe just out side of MH has back fall of 1.3%. 3% of fall through MH

**Corrections:**

Sincerely,

Jeff Hill  
Engineering Tech IV  
Jhill@PuyallupWA.gov  
(253) 841-5424