



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 11, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** E-21-0426

**Property Address:** 2902 E PIONEER ;

**Contractor:** MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

**To construct:** SEWER, CF &G ~ EAST TOWN CROSSING

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** McKee and DGS finished the dewatering install and discharge tie in to the off site storm. Abbey Road is the CESCL and will be monitoring the discharge.

I asked the review engineer to take a look at the sewer next to the traffic signal. The city's traffic department had concerns for the weakening of the ground near that base.

**Corrections:**

Sincerely,

Jason Little  
Engineering Tech IV



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

JLittle@PuyallupWA.gov

(253) 435-3636