



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 12, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** E-21-0426

**Property Address:** 2902 E PIONEER ;

**Contractor:** MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

**To construct:** SEWER, CF &G ~ EAST TOWN CROSSING

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** DGS is on site maintaining the pump and well points. draw down was at 13' this morning. McKee was notified yesterday of the MLK holiday for Monday. The design engineer is working on a solution for the sewer next to the traffic signal base. Abbey Road has come up with a solution. I forwarded to the city's reviewer.

**Corrections:**

Sincerely,

Jason Little  
Engineering Tech IV



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

JLittle@PuyallupWA.gov

(253) 435-3636