



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
F-21-0125

FIRE ALARMS

Puyallup, WA

Job Address	Address: 150 RIVER RD, PUYALLUP, WA 98371 Parcel # 0420281162	ISSUED January 19, 2022
Owner	SOUTHWEST CORNER PROPERTIES LL 100 RIVER RD PUYALLUP, WA 98371-4161	
Applicant	SONITROL PACIFIC 5911 ORCHARD ST W TACOMA, WA 98409 (425) 258-3655 Keliyah Quincy 2221 California St Everett, WA 98201 (425) 583-9657 KeliyahQ@verifiedpeaceofmind.com	
Contractor	SONITROL PACIFIC 5911 ORCHARD ST W TACOMA, WA 98409 keliyahq@verifiedpeaceofmind.com WA L&I #:	
Description of Work	INSTALL TG-F7S TO MONITORING EXISTING FIRE ALARM	
Permit Types	Fire Alarms	
Expiration Date:	July 18, 2022	

Building Components:

Quantity	Units	Description	Unit Cost	Subtotal Cost
1	DEVICES	Fire Alarm and Detection System and Related Equipment, Alteration	\$0.00	\$0.00
			Total Value of Work:	\$0.00

Standard Conditions:

1. PERMIT CONDITIONS:

- 1- APPOINTMENT REQUIRED FOR ALL INSPECTIONS AM/PM IS NOT GUARANTEED WITHOUT APPOINTMENT. LARGER SYSTEMS TAKING MORE THAN 1 HOUR WILL REQUIRE 48-72HR NOTICE PRIOR TO SCHEDULING. INSECTIONS ARE MONDAY-THURSDAY, NO FRIDAY INSPECTIONS
- 2- PROVIDE PLANS AND PERMIT ON SITE FOR INSPECTION.
- 3- COMPLETE LABOR AND INDUSTRIES INSPECTIONS PRIOR TO REQUESTING CITY INSPECTION.
- 4- DEVICE MAPS REQUIRED AT THE ANNUNCIATOR AND FIRE ALARM PANEL PRIOR TO CALLING IN FINAL. THE ANNUNCIATOR MAP WILL NEED TO BE WEATHERPROOF.
- 5- TOTAL COVERAGE IS REQUIRED, SUBJECT TO FIELD INSPECTION. COMPLY WITH NFPA 72, 2016
- 6- FIRE ALARM SYSTEM SHALL BE PLACARDED PER NFPA 72. THE UL CERTIFICATE SHALL BE POSTED AT TIME OF FINAL INSPECTION. THE SYSTEM WILL NEED TO BE UL CERTIFIED.
- 7- A PRE-TEST SHALL BE CONDUCTED AND A PRINTOUT OF THE LOCATION OF THE DEVICE, POINT NUMBER AND DESCRIPTOR SHALL BE FURNISHED TO THE INSPECTOR AT FINAL. LABELING OF ALL DEVICES ABOVE AND BELOW CEILING REQUIRED.

8- THE CITY OF PUYALLUP ALLOWS ONE FACP PER BUILDING. THE PANEL WILL NEED TO BE LARGE ENOUGH TO HANDLE MULTIPLE TENANTS IF APPLICABLE.

INSPECTION REQUEST CODES:

5302 FIRE ALARM TEST INSPECTION

5303 FIRE ALARM FINAL INSPECTION

SCHEDULE YOUR INSPECTION BY PHONE OR ONLINE THROUGH THE CITY OF PUYALLUP ONLINE PERMIT SYSTEM. THEN CALL MORNING OF INSPECTION BETWEEN 7AM – 8AM TO SET UP A TIME. CONTRACTOR MUST BE PRESENT. INSPECTIONS ARE MONDAY – THURSDAY THERE WILL BE NO INSPECTIONS ON FRIDAYS.

[HTTPS://SECURE.CITYOFPUYALLUP.ORG/](https://secure.cityofpuyllup.org/)

INSPECTION LINE 1-877-232-6456 (USE MUTE TO AVOID BACKGROUND NOISE)

DAVID DRAKE AT 253-864-4171 OR RAY COCKERHAM AT 253-841-5585

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:

SONITROL PACIFIC Keliyah Quincy