



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 20, 2022

Inspection Result: PASSED

Permit Number: B-19-1101

Property Address: 3500 S MERIDIAN ;

Contractor: ALEGIS CONSTRUCTION INC 6900 SW ATLANTA ST. BLDG PORTLAND, OR 97223

To construct: INTERIOR DEMO AND SOME SEISMIC UPGRADES ~ ROUND 1
ENTERTAINMENT VENUE
TRAFFIC IMPACT FEES TO BE ASSESSED DURING PENDING TI BUILDING PERMIT - BR
BLDG/MECH

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; slab dowels complete at plumbing trench pour back of slab.

Corrections:

- 1 ; complete install of slab dowels at plumbing trench pour back. (vapor barrier complete)

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org