



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 20, 2022

Inspection Result: PARTIAL PASS

Permit Number: B-21-0583

Property Address: 507 31ST AVE SW, PUYALLUP, WA 98373;

Contractor: SUPERIOR BUILDERS INC PO BOX 1849 FIFE, WA 98354-1849

To construct: TI COMBINE (2) SUITES INTO 1 OFFICE ~ STEWART TITLE

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: INSP WALLBOARD / DRYWALL - approved walls only

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684