



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 18, 2022

Inspection Result: **FAILED**

Permit Number: B-21-0386

Property Address: 2504 E MAIN, PUYALLUP, WA 98372;

Contractor: POE CONSTRUCTION PO BOX 1838 AUBURN, WA 98071-0899

To construct: TI - NEW OFFICE SPACE MEZZANINE WITHIN EXISTING WAREHOUSE ~
IDI LOGISTICS
BLDG ONLY

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 ; provide electrical and fire cover approval prior to ceiling grid inspection.
- 2 ; complete all mechanical rough-in of duct work and complete install of diffusers with positive connection to main and cross-tee of ceiling grid.
- 3 ; complete all ceiling grid requirements as per city approved plans prior to inspection - not ready

Sincerely,

Gary Webster

Building Inspector

GWebster@PuyallupWA.gov

(253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org