



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 24, 2022

Inspection Result: PARTIAL PASS

Permit Number: B-19-0402

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: TI ~ GSH RENOVATE 1ST FL PATIENT WING FOREST PAVILION PATIENT SLEEP/CARE

BLDG/MECH/PLUMB

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: INSP FRAME - No Comments

Corrections:

- 1 1 ; complete nailplates at electrical as discussed with contractor.
- 2 ; complete fireproofing at steel columns and cross beams.
- 3 ; toilet to be 16"-18" from wall to center line of toilet in room 183A.
- 4 ; inspection of rooms - (164,166,168,170,172,174,178,180,182,184,186;188,187,185,183,181) ok to cover

Sincerely,

Shannon King



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684