



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 26, 2022

Inspection Result: **FAILED**

Permit Number: B-21-0544

Property Address: 4423 S MERIDIAN;

Contractor: PROBUILD CONSTRUCTION 12112 92ND AVE CT E PUYALLUP, WA 98373

To construct: TI ~ TANDOORI GRILL

BLDG/PLUMB/MECH

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: INSP COMBINATION FRAME AND ROU - No Comments

Corrections:

- 1 1 ; provide complete set of city approved plans on-site at time of inspection. (inspection of below slab plumbing only)
- 2 ; provide as built plumbing plan approval from engineer of record.
- 1 ; remove abandoned plumbing and cap below slab prior to below slab inspection.
- 4 ; provide test on D.W.V. with 10' head test at time of inspection.

Sincerely,

Shannon King



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684