



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 19, 2022                      **Inspection Result:**     **FAILED**

**Permit Number:** B-19-1101

**Property Address:** 3500 S MERIDIAN                      ;

**Contractor:** ALEGIS CONSTRUCTION INC 6900 SW ATLANTA ST. BLDG PORTLAND,  
OR 97223

**To construct:** INTERIOR DEMO AND SOME SEISMIC UPGRADES ~ ROUND 1  
ENTERTAINMENT VENUE  
TRAFFIC IMPACT FEES TO BE ASSESSED DURING PENDING TI BUILDING  
PERMIT - BR  
BLDG/MECH

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** INSP FOUNDATION/REBAR - No Comments

**Corrections:**

- 1 ; complete install of slab dowels at plumbing trench pour back. ( vapor barrier complete)

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)