



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 31, 2022

Inspection Result: **FAILED**

Permit Number: B-20-0235

Property Address: 2504 E MAIN, PUYALLUP, WA 98372;

Contractor: POE CONSTRUCTION PO BOX 1838 AUBURN, WA 98071-0899

To construct: TILT UP WAREHOUSE ~ PUYALLUP CORPORATE CENTER

BLDG/MECH/DEEP UNDERGROUND PLUMB

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: INSP COMMENT -see final inspection corrections

Corrections:

- 1
- 2 onsite for final building inspection

Sincerely,

Gary Webster

Building Inspector

GWebster@PuyallupWA.gov

(253) 841-5590