



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 04, 2022 **Inspection Result:** **PARTIAL PASS**

Permit Number: E-21-0068

Property Address: 3500 S MERIDIAN ;

Contractor: ROD BANE MANAGEMENT DBA RBM 6668 E OLIVE AVE FRESNO, CA
93727

To construct: GREASE INTERCEPTOR~ ROUND 1 BOWLING & AMUSEMENT

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Contractor cleaned up sidewalk area and lid of fire vault. Fire vault needs to be opened to view cleanliness due to spoil pile being dumped on top. PIV tamper switch needs to be repaired due to contractor hitting it. Vent needs to be raised before dirt clogs it.

Corrections:

- 1 Fire vault needs to be opened to view cleanliness due to spoil pile being dumped on top. PIV tamper switch needs to be repaired due to contractor hitting it. Vent needs to be raised before dirt clogs it. Landscape needs to be finished.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by several vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends from the end of the signature to the right.

Jason Little
Engineering Tech IV
JLittle@PuyallupWA.gov
(253) 435-3636