



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 04, 2022

Inspection Result: **FAILED**

Permit Number: B-21-0544

Property Address: 4423 S MERIDIAN;

Contractor: PROBUILD CONSTRUCTION 12112 92ND AVE CT E PUYALLUP, WA
98373 Alex Rodriguez 12112 92ND AVE CT E SOUTH HILL, WA 98373
(253) 844-7547

To construct: TI ~ TANDOORI GRILL

BLDG/PLUMB/MECH

On this day we have inspected your construction for **Grease Interceptor Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: No compaction on ditches, cast iron sewer needs to be added, and site needs to be cleaned up prior to rain.

Corrections:

- 1 No compaction on ditches, cast iron sewer needs to be added, and site needs to be cleaned up prior to rain.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little
Engineering Tech IV
JLittle@PuyallupWA.gov
(253) 435-3636