



CITY OF PUYALLUP
Development & Permitting Services
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Permit No:
PRFA20210080

FIRE ALARMS

Puyallup, WA

Job Address	Address: 3213 WILDWOOD PARK DR, PUYALLUP, WA 98374 Parcel # 0419023002	ISSUED February 09, 2022
Owner PUYALLUP SCH DIST #3 3213 WILDWOOD PARK DR PUYALLUP, WA 98371-0156		
Applicant William Blais 11000 184th ave e bonney lake, WA 98391 (206) 665-0333 wblais@gostructured.com		
Contractor STRUCTURED COMMUNICATIONS P.O. BOX 1368 SNOHOMISH, WA 98291 WBLAIS@GOSTRUCTURED.COM WA L&I #: STRUCTURED COMMUNICATIONS P.O. BOX 1368 SNOHOMISH, WA 98291 WBLAIS@GOSTRUCTURED.COM WA L&I #:		
Description of Work Design, Procurement, and Installation of an Emergency Responder Radio Communication System. (ERRCS) to provide 1st responder radio communication amplification within the building to meet IFC code requirements.		
Permit Types	Fire Alarms	
Expiration Date: August 08, 2022		

Building Components:

Quantity	Units	Description	Unit Cost	Subtotal Cost
20	DEVICES	Fire Alarm and Detection System and Related Equipment, New	\$0.00	\$0.00
Total Value of Work:				\$0.00

Standard Conditions:

1. 1- Email Ron Taylor for all required Radio frequencies ron@rtfidelity.solutions
 - a. Cc. ddrake@puyallupwa.gov
 - b. Cc. rayc@puyallupwa.gov
 - c. Responding agencies are Central Pierce Fire & Rescue, Puyallup Police Department
- 2- Prior to requesting City Inspection, reply to email chain above with passing test results and include all frequencies tested in a full report.
- 3- Once the report has been reviewed, a request for inspection can be approved.
- 4- Appointment required for inspection.
- 5- Fire Alarm contractor required to be onsite for testing.
- 6- Provide plans and permit on site for inspection.
- 7- A smoke detector is required above riser.
- 8- Complete labor and industries inspections prior to requesting city inspection.

Schedule your inspection online through the city of puyallup online permit system after requesting appointment from inspector.
Fire Inspections are Monday – Thursday there will be no inspections on Fridays.
David Drake 253-864-4171 ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
William Blais