



CITY OF PUYALLUP  
**Development & Permitting Services**  
 333 S. Meridian, Puyallup, WA 98371  
 (253) 864-4165  
[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

**Permit No:**  
 PRFA20210032

## FIRE ALARMS

Puyallup, WA

<b>Job Address</b>	Address: 333 S MERIDIAN, Unit: 400, PUYALLUP, WA 98371 Parcel # 5745001080	<b>ISSUED</b> February 10, 2022
<b>Owner</b>	CITY OF PUYALLUP 333 S MERIDIAN PUYALLUP, WA 98371-5904 (253) 841-5509	
<b>Applicant</b>	Firepower, Inc. 10220 N. Nevada St, Suite 80 Spokane, WA 99218 (509) 468-3204 angelt@firepowerinc.org	
<b>Contractor</b>	FIREPOWER INC 10220 N NEVEDA ST#130 SPOKANE, WA 99218 WSUMMERS@FIREPOWERINC.ORG WA L&I #:	
<b>Description of Work</b>	add a smoke detector on the 4th floor for an office at city hall of Puyallup	
<b>Permit Types</b>	Fire Alarms	
<b>Expiration Date:</b>	July 12, 2022	

### Building Components:

Quantity	Units	Description	Unit Cost	Subtotal Cost
1	DEVICES	Fire Alarm and Detection System and Related Equipment, Alteration	\$0.00	\$0.00
			<b>Total Value of Work:</b>	\$0.00

### Standard Conditions:

1. 1- APPOINTMENT REQUIRED FOR ALL INSPECTIONS
- 2- PROVIDE PLANS AND PERMIT ON SITE FOR INSPECTION.
- 3- COMPLETE LABOR AND INDUSTRIES INSPECTIONS PRIOR TO REQUESTING CITY INSPECTION.
- 4- A REMOTE ANNUNCIATOR LOCATED ON THE EXTERIOR OF THE MAIN ENTRANCE IN A WEATHER PROOF HOUSING REQUIRED.
- 5- EXTERIOR FIRE BELL REQUIRED OUTSIDE FIRE SPRINKLER ROOM.
- 6- DEVICE MAPS REQUIRED AT THE ANNUNCIATOR AND FIRE ALARM PANEL PRIOR TO CALLING IN FINAL. THE ANNUNCIATOR MAP WILL NEED TO BE WEATHER PROOF.
- 7- TOTAL COVERAGE IS REQUIRED; SUBJECT TO FIELD INSPECTION. COMPLY WITH NFPA 72, 2013
- 8- FIRE ALARM SYSTEM SHALL BE PLACARDED PER NFPA 72. THE UL CERTIFICATE SHALL BE POSTED AT TIME OF FINAL INSPECTION. THE SYSTEM WILL NEED TO BE UL CERTIFIED.
- 9- A PRE-TEST SHALL BE CONDUCTED AND A PRINT OUT OF THE LOCATION OF THE DEVICE, POINT NUMBER AND DESCRIPTOR SHALL BE FURNISHED TO THE INSPECTOR AT FINAL.
- 10- FIRE SPRINKLER TAMPER VALVES AND PIV WILL BE REQUIRED TO BE TESTED AT INSPECTION. FIRE SPRINKLER CONTRACTOR TO BE ONSITE.

11- THE CITY OF PUYALLUP ALLOWS ONE FACP PER BUILDING. THE PANEL WILL NEED TO BE LARGE ENOUGH TO HANDLE MULTIPLE TENTANTS IF APPLICABLE.

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

**I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.**

**Applicant:**  
Firepower, Inc.