

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

| Date of Inspection: | Feb 18, 2022 | Inspection Result: | PARTI | AL PASS |
|-------------------------------------|------------------------------------|---------------------|-----------|-------------|
| Permit Number: Property Address: | 2 20 0701 | | | |
| Contractor: | ROD BANE MANAGEME 93727 | NT DBA RBM 6668 E C | DLIVE AVE | Fresno, ca |
| To construct: | TI - EXISTING SEARS/ BU ROUND 1 | JILDING INTO BOWLIN | IG & ARCA | ADE VENUE ~ |

BLDG/PLUMB/MECH

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: INSP PLUMBING ROUGH IN - supply & d/w/v - ok 1 provide hammer arrestor @ urinals

Corrections:

1 provide hammer arrestor @ urinals as discussed

Sincerely,

Gary Webster Building Inspector GWebster@PuyallupWA.gov (253) 841-5590