



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 24, 2022 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRFUP20210127

Property Address: 2504 E MAIN, PUYALLUP, WA 98372;

Contractor: NORTH SKY - CENTURY LINK 11818 SE MILL PLAIN BLVD VANCOUVER, WA 98684

To construct: Transfer facilities to four relocated PSE poles. Transfer overhead drop on one relocated PSE pole. Bore across E main Ave to place (1) 4" conduit to MH 24 to pull in new copper cable.

On this day we have inspected your construction for **Job Start Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 444 splice vault installed, cable rerouted, the vault was set low to be paved over and must be raised to finish grade.

Corrections:

- 1 444 vault lid must be raised to finish grade

Sincerely,

Jeff Hill
Engineering Tech IV
Jhill@PuyallupWA.gov
(253) 841-5424