


Reviewed 2/15/2022 DL Subject to field inspectors approvals.



913 S. Kay Avenue
Addison, IL 60101
800-666-CURB (2872)
Fax: 630-543-5309
www.thybar.com



Seismic /97 MPH Wind Load Design Calculations for a

LG LUU369HV (CU-1,5,6) on a

**Thybar Retromate
at 1201 39th Ave SW, Puyallup WA 98373**

**Costco 660 - Puyallup, WA
Thybar Order # 215746**

October 27, 2021

**THE APPROVED CONSTRUCTION
PLANS AND ALL DOCUMENTS
DOCUMENTS MUST BE POSTED ON
THE JOB AT ALL INSPECTIONS IN A
VISIBLE AND READILY ACCESSIBLE
LOCATION.**

This document contains proprietary information from Thybar Corporation. Its contents may not be used for any other project or location other than the project or location for which it was created without the prior written permission of Thybar Corporation.

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW, Puyallup WA 98373

Seismic Design Category: D

Summary

Assumptions

Review all pages prior to installing

1. These calculations begin with the assumption that the Thybar Retromates is supported around its full perimeter by the existing curb.
2. The Thybar Retromate must be attached to the existing curb using welds or bolts at the Retromate base flanges. The existing curb is assumed to be of sufficient structural integrity to withstand all seismic and wind load forces transmitted to it by the Retromate. Thybar Corporation is not responsible for verification of existing curb structural integrity and verification of building structure supporting the existing and new adapter curb is not the responsibility of Thybar Corporation.
3. As curb manufacturers, Thybar Corporation cannot be expected to provide appropriate attachment hardware for every possible type of roof structure. Thybar provides seismic/wind load calculations that are based on the material provided; typically sheet metal curbs. It is the responsibility of others (project engineer, architect, SEOR, etc.) to know enough about the load carrying capability of the building structure to design a method of attachment to that structure. Thybar does not design the structure and therefore should not recommend an attachment method that may create difficulties with existing field conditions outside of the curb manufacturer's control.

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW, Puyallup WA 98373

Seismic Design Category: D

Equipment			
Manufacturer	LG		
Unit Model	LUU369HV (CU-1,5,6)		
Base Length	24 3/8 in	CG _{x1}	14.64 in
Base Width	14 3/16 in	CG _{y1}	8.51 in
Height	54 3/8 in	Top Area A _t	3.7 ft ²
Unit Weight	199 lbs.	Long Side Area	14.1 ft ²
Total Operating Weight	199 lbs.	Short Side Area	5.4 ft ²

Thybar Product							
Product	TEMS3 Short Side				TEMS Qty.	2	
TEMS Length	35 in	TEMS Offset	24 7/16 in	Min. Height	3.00 in	Max. Height	3.00 in
Material	14 Ga. Prime Galv Steel		Thickness	0.0713 in	Est. Weight	50 lbs.	
Poisson's Ratio ν	0.297		Yield Strength F _y	33,000 psi		Flat height of curb wall h	2.71 in
Tensile Strength F _u	45,000 psi		Young's Modulus E	29,000,000 psi			

Wind Load Factors		Seismic Load Factors	
Exposure Category	B	Site Soil Classification	D
Height for Wind Calculations	30.0 ft.	Occupancy/Risk Category	II
Wind Speed V	97 MPH	S _s (% of g)	126.70%
Velocity Pressure coefficient K _z	0.70	S ₁ (% of g)	43.70%
Topography factor K _{zt}	1.00	S _{D5}	1.014
Directionality factor K _d	0.85	a _p	2.50
qh	14.14	I _p	1.00
Importance factor I _w	N/A	R _p	6.00
GCr	1.90	Snow Load	
GC (Uplift)	1.50	C _t	1.1
Ke	0.99	C _E	1
		Snow Importance, I	1.0
		Unit Roof Snow Load	11.6 lb/ft ²

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: Retromate

Unit Manufacturer / Model: LG LUU369HV (CU-1,5,6)

Unit Forces		
Unit Height	H	54.34 in
Unit COG	CG _y	8.51 in
Unit COG	CG _x	14.64 in
Unit COG	CG _z	27.19 in
Total Operating Weight	W _u	199 lbs.
Weight Long Side	W _{ul}	199 lbs.
Weight Short Side	W _{us}	199 lbs.
Snow Load	SL	42 lbs.
Snow Long Side	SL _l	42 lbs.
Snow Short Side	SL _s	42 lbs.
Wind Load (97 mph) Long Side	F _{wu}	379 lbs.
Wind Load (97 mph) Short Side	F _{wu}	144 lbs.
Wind Upward Force	F _{up}	78 lbs.
Seismic Force	F _{eu}	101 lbs.
	F _{eu Max}	323 lbs.
	F _{eu Min}	61 lbs.
Seismic Vertical ± Force	F _{upu}	40 lbs.
	z / h	1.0

Long Side Loading	Short Side Loading

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: TEMS3 Short Side

Unit Manufacturer / Model: LG LUU369HV (CU-1,5,6)

TEMS Forces				Maximum Total Loading on Screw			
TEMS Max Height	h	3.00 in		Uplift Long Side	0.6D+0.6W	Pw	411 lbs.
Centerline Width	w	14.19 in		Shear Long Side	0.6D+0.6W	Sw	227 lbs.
TEMS Weight	W_c	50 lbs.		Uplift Short Side	0.6D+0.6W	Ps	70 lbs.
Wind Load (97 mph) Long Side	F_{wc}	2 lbs.		Shear Short Side	0.6D+0.6W	Ss	86 lbs.
Wind Load (97 mph) Short Side	F_{wc}	20 lbs.		Maximum Load at TEMS			
Seismic Force	F_{ec}	25 lbs.		Axial Load Long	D+0.6W	Tw	531 lbs.
	$F_{ec Max}$	81 lbs.		Shear Long	D+0.6W	Sw	227 lbs.
	$F_{ec Min}$	15 lbs.		Axial Load Short	D+0.7E	Ts	270 lbs.
TEMS Seismic Vertical \pm Force	F_{upc}	10 lbs.		Shear Short	D+0.6W	Ss	86 lbs.
				Maximum Load at TEMS Base			
				Uplift Long Side	0.6D+0.6W	Pw	135 lbs.
				Shear Long Side	0.6D+0.6W	Sw	230 lbs.
				Uplift Short Side	0.6D+0.6W	Ps	45 lbs.
				Shear Short Side	0.6D+0.6W	Ss	110 lbs.
Long Side Loading				Short Side Loading			

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018


Location: 1201 39th Ave SW
 Puyallup, WA 98373

Seismic Design Category: D

Curb Type: TEMS3 Short Side

Unit Manufacturer / Model: LG LUU369HV (CU-1,5,6)

Unit to TEMS Screw Design				
Unit and TEMS			Screw Capacity	
	Long	Short	Screw size/type (#)	1/4 304 SS
Unit Shear	227 lbs.	86 lbs.	Hole size	0.25 in
Unit Uplift	411 lbs.	70 lbs.	Allowable pullout/screw	1400 lbs.
TEMS Length and Offset	35.00 in	24.44 in	Allowable shear/screw	746 lbs.
			Long	
			Tension on Screws	411 lbs.
			Shear on Screws	114 lbs.
			# Screws for pullout/side	2
			# Screws for Shear/side	2
			Combined loading check If < 1	Ok 0.223



Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D



Curb Type: TEMS3 Short Side

Unit Manufacturer / Model: LG LUU369HV (CU-1,5,6)

TEMS Base Hole	
Material Properties	
F_y	33,000 psi
F_u	45,000 psi
Base Hole Dimensions	
Hole Size	0.6250 in
Fastener Diameter	1/2 in
Material thickness	14 Ga.
TEMS flange thickness t_f	0.1426 in
Cut out area	0.31 in ²
Base flange width	2.0000 in
Edge distance	0.6875 in
Base shear area A_n	0.20 in ²
Bearing strength w/o bolt hole deformation AISI Section J3.3.1	
P_n	7,219 lbs.
Allowable Bearing P_{all}	2,888 lbs.
TEMS Base Hole Forces Short Side Loading	
Shear V_s	55 lbs.
Uplift T_s	58 lbs.
$R = \sqrt{T^2 + V^2}$ R_s	80 lbs.
Min. Holes per TEMS side R/Pall	2
TEMS Base Hole Forces Long Side Loading	
Shear V_L	29 lbs.
Uplift T_L	23 lbs.
$R = \sqrt{T^2 + V^2}$ R_L	37 lbs.
if R/Pall is < 1 number of holes OK	0.01
Shear Strength AISI Section J6.1	
V_n	5,294
Allowable Shear V_{all}	2,385
	LS Loading SS Loading
Min. Holes per TEMS side R/V_{all}	1 1
Base Holes	
Min. Holes per TEMS Long Side	2
Shear per Hole	14 lbs.
Uplift per Hole	11 lbs.
<p>Use screws at 18" min.: Long Side = 4 Short Side = 3</p> <p>The screws must be drilled into the existing curb steel at the attachment of the retromate to the existing curb.</p>	
<p>As curb manufacturers, Thybar Corporation cannot specify the appropriate attachment hardware for every possible type of roof structure. Thybar provides seismic/wind load calculations that are based on the material provided; typically sheet metal curbs. It is the responsibility of others (project engineer, architect, SEOR, etc) to design a method of the TEMS attachment to that structure. Thybar does not design the structure and therefore cannot recommend an attachment method that may create difficulties with existing field conditions outside of the curb manufacturer's control.</p>	

Thybar Model Restraints	Bolt Qty. Per Unit	Attachment Screws	Product
N/A	4	(4) 1/4" Dia. 304 SS Bolts with Nuts	

Unit to Curb Screw Installation Instructions
1. Unit directly connected to the top of Terms at specified unit location



DETAIL

Min Base Hole Quantity per side: 4 3 0.25

⚡ VERIFY ALL ELECTRICAL WIRES ARE CLEAR OF BASE RAIL INTERIOR BEFORE INSTALLING RESTRAINT

<p>Seismic / Wind load Restraint for LG LLU369HV On a Thybar Retromate with Equipment Bases Costco 660 - Puyallup, WA 1201 39th Ave SW, Puyallup WA 98373</p>		<p>Qty: 1 Job# 215746 Tag: ((CU-1,5,6)) Drawing is conceptual, not to scale Page 8 of 8</p>
<p>The information contained in this drawing is the sole property of Thybar Corporation. Any reproduction in part or whole without the written consent of Thybar Corporation is prohibited.</p>		<p>(DO NOT SCALE DRAWING) Unless otherwise specified dimensions are in inches tolerances are ± 1/16 ± 0.0625 ± 1° Date 10/27/2021</p>
<p>(Holes start 6 in. from base OD)</p>	<p>Long Short Hole Size</p>	<p>Meets Requirements for: IBC2018 Seismic Design Category: D Max. Wind Speed: 97 MPH Building Height: 30 ft. Exposure Category: B Risk Category: II</p>
<p>Seismic & Wind load Restraints are designed & calculated for use in Seismic & Wind load applications when provided as part of a Seismic & Wind load rated Thybar curb. Attachment of calculated Restraint to any other curb does not constitute a Seismic & Wind load rated assembly. Thybar Corporation has a policy of continuous product improvement and reserves the right to change the product design without notice.</p>		
<p>thybar CORPORATION Thybar makes it right the first time, every time.</p>		

City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic



913 S. Kay Avenue
Addison, IL 60101
800-666-CURB (2872)
Fax: 630-543-5309
www.thybar.com



Seismic /97 MPH Wind Load Design Calculations for a

Aaon RN-006 (AC-4) on a

**Thybar Retromate
at 1201 39th Ave SW, Puyallup WA 98373**

**Costco 660 - Puyallup, WA
Thybar Order # 215746**

October 27, 2021

This document contains proprietary information from Thybar Corporation. Its contents may not be used for any other project or location other than the project or location for which it was created without the prior written permission of Thybar Corporation.

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW, Puyallup WA 98373

Seismic Design Category: D

Summary

Assumptions

Review all pages prior to installing

1. These calculations begin with the assumption that the Thybar Retromates is supported around its full perimeter by the existing curb.
2. The Thybar Retromate must be attached to the existing curb using welds or bolts at the Retromate base flanges. The existing curb is assumed to be of sufficient structural integrity to withstand all seismic and wind load forces transmitted to it by the Retromate. Thybar Corporation is not responsible for verification of existing curb structural integrity and verification of building structure supporting the existing and new adapter curb is not the responsibility of Thybar Corporation.
3. As curb manufacturers, Thybar Corporation cannot be expected to provide appropriate attachment hardware for every possible type of roof structure. Thybar provides seismic/wind load calculations that are based on the material provided; typically sheet metal curbs. It is the responsibility of others (project engineer, architect, SEOR, etc.) to know enough about the load carrying capability of the building structure to design a method of attachment to that structure. Thybar does not design the structure and therefore should not recommend an attachment method that may create difficulties with existing field conditions outside of the curb manufacturer's control.

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW, Puyallup WA 98373

Seismic Design Category: D

Equipment			
Manufacturer	Aeon		
Unit Model	RN-006 (AC-4)		
Base Length	82 in	CG _{x1}	44.00 in
Base Width	43 3/4 in	CG _{y1}	15.35 in
Height	44 in	Top Area A _t	50.2 ft ²
Unit Weight	1,247 lbs.	Long Side Area	26.4 ft ²
Total Operating Weight	1,247 lbs.	Short Side Area	18.7 ft ²

Thybar Product							
Product	Insulated Roof Curb No Top Nailers					1	
Length OD	77 1/2 in	Width OD	39 1/4 in	Min. Height	12.00 in	Max. Height	12.00 in
Material	14 Ga. Prime Galv Steel		Thickness	0.0713 in	Est. Weight	127 lbs.	
Poisson's Ratio ν	0.297		Yield Strength F _y	33,000 psi		Flat height of	curb wall h
Tensile Strength F _u	45,000 psi		Young's Modulus E	29,000,000 psi		11.71 in	

Diagram Dimensions: 77 1/2 in (width), 39 1/4 in (height). Corner Heights: 12.000 in. Top edge: Return End.

Wind Load Factors		Seismic Load Factors	
Exposure Category	B	Site Soil Classification	D
Height for Wind Calculations	30.0 ft.	Occupancy/Risk Category	II
Wind Speed V	97 MPH	S _s (% of g)	126.70%
Velocity Pressure coefficient K _z	0.70	S ₁ (% of g)	43.70%
Topography factor K _{zt}	1.00	S _{DS}	1.014
Directionality factor K _d	0.85	S _{D1}	0.000
qh	14.14	F _a	1.20
Importance factor I _w	N/A	F _v	0.00
GCr	1.90	Snow Load	
GC (Uplift)	1.50	C _t	1.1
Ke	0.99	C _E	1
		Snow Importance, I	1.0
		Unit Roof Snow Load	11.6 lb/ft ²

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: Retromate

Unit Manufacturer / Model: Aeon RN-006 (AC-4)

Unit Forces		
Unit Height	H	44.00 in
Unit COG	CG _y	15.35 in
Unit COG	CG _x	44.00 in
Unit COG	CG _z	22.00 in
Total Operating Weight	W _u	1,247 lbs.
Weight Long Side	W _{ul}	828 lbs.
Weight Short Side	W _{us}	419 lbs.
Snow Load	SL	580 lbs.
Snow Long Side	SL _l	385 lbs.
Snow Short Side	SL _s	195 lbs.
Wind Load (97 mph) Long Side	F _{wu}	709 lbs.
Wind Load (97 mph) Short Side	F _{wu}	502 lbs.
Wind Upward Force	F _{up}	1,064 lbs.
Seismic Force	F _{eu}	632 lbs.
	F _{eu Max}	2,024 lbs.
	F _{eu Min}	379 lbs.
Seismic Vertical ± Force	F _{upu}	253 lbs.
	z / h	1.0

Long Side Loading	Short Side Loading

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: Retromate

Unit Manufacturer / Model: Aaon RN-006 (AC-4)

Curb Forces				Maximum Total Loading on Bracket			
Curb Max Height	h	12.00 in		Uplift Long Side	$0.6D+0.6W$	Pw	307 lbs.
Centerline Width	w	41.25 in		Shear Long Side	$0.6D+0.6W$	Sw	213 lbs.
Curb Weight	W_c	127 lbs.		Uplift Short Side	$0.6D+0.6W$	Ps	62 lbs.
Wind Load (97 mph) Long Side	F_{wc}	173 lbs.		Shear Short Side	$0.6D+0.6W$	Ss	151 lbs.
Wind Load (97 mph) Short Side	F_{wc}	88 lbs.		Maximum Load at Curb			
Seismic Force	F_{ec}	64 lbs.		Axial Load Long	$D+0.75(0.7E)+0.75S$	Twc	1,459 lbs.
	$F_{ec\ Max}$	205 lbs.		Shear Long	$D+0.7E$	Swc	221 lbs.
	$F_{ec\ Min}$	39 lbs.		Axial Load Short	$D+0.75(0.7E)+0.75S$	Tsc	1,154 lbs.
Curb Seismic Vertical \pm Force	F_{upc}	26 lbs.		Shear Short	$D+0.7E$	Ssc	221 lbs.
				Maximum Load at Curb Base			
				Uplift Long Side	$0.6D+0.6W$	Pwb	391 lbs.
				Shear Long Side	$0.6D+0.6W$	Swb	265 lbs.
				Uplift Short Side	$0.6D+0.7E$	Psb	0 lbs.
				Shear Short Side	$0.6D+0.7E$	Ssb	244 lbs.
Long Side Loading				Short Side Loading			

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018


Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: Retromate

Unit Manufacturer / Model: Aeon RN-006 (AC-4)

Unit to Curb Bracket Design			
Unit and Curb		Screw Capacity @ Side of Bracket	
	Long	Short	
Unit Shear	213 lbs.	151 lbs.	Screw size/type (#)
Unit Uplift	307 lbs.	62 lbs.	Hole size
Curb Length/Width	77.50 in	39.25 in	Allowable pullout/screw
			Allowable shear/screw
			463 lbs.
Bracket Dimensions		Long	Short
Length L	8.00 in	Tension on Screws	213 lbs. 75 lbs.
Max bending arm BA	1.88 in	Shear on Screws	307 lbs. 62 lbs.
Gauge	10 Ga	# Screws for pullout/Bracket	4
thickness t	0.1220 in	# Screws for Shear/Bracket	4
Yield Strength F_y	50,000 psi	Combined loading check $I_f < 1$ Ok	0.026
Cross Sectional Area	0.98 in ²	Screw Capacity @ Top of Bracket	
Bracket Flexure Capacity		Screw size/type (#)	10
F_y	50,000 psi	Hole size	0.25 in
Allowable Uplift T_a	475 lbs.	Allowable pullout/screw	145 lbs.
		Allowable shear/screw	404 lbs.
Bracket Quantity		Long	Short
	Long	Short	
Brackets Required, # per side	2	0	Tension on Screws T_c
Total Brackets Required	4		Shear on Screws
			# Screws for pullout/Bracket
			# Screws for Shear/Bracket
			Combined loading check $I_f < 1$ Ok
			0.074
Bracket Shear Capacity at Holes			
			Max Shear / Bracket
			hole edge to bracket edge e
			Allowable shear stress F_v
			Allowable shear / Bracket P_s
			153 lbs.
			0.375 in
			30,000 lbs.
			5,490 lbs.



Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: Retromate

Unit Manufacturer / Model: Aeon RN-006 (AC-4)

Curb Wall Design		
Compression of Curb Wall		
	K	4
	f_{cr}	528 psi
	F_a	264 psi
Material thickness	t	0.071 in
	P	729 lbs.
stiffeners Required	b	31.74
	OK f_a	264 psi
	OK Lc/ts	164
Shear on Short Side of Curb Wall		
	α	3.35
	K_s	5.70
	f_{cr}	5,520 psi
	F_v	2,760 psi
	f_v	40 psi
stiffeners Design		
stiffeners Width	ws	1.00 in
stiffeners Thickness	ts	0.071 in
stiffeners Length	Lc	11.715 in
	ws/ts	14.03
	$0.42\sqrt{E/F_y}$	12.45
	weff	0.888 in
Bearing Stiffener Capacity per AISI F5.1 (a)		
	A_s	0.06 in ²
	A_c	0.15 in ²
	P_n	5,108 lbs.
	P_{all}	2,554 lbs.
Bearing Stiffener Capacity per AISI F5.1 (b)		
	A_b	0.19 in ²
	F_e	136,965 psi
	F_n	29,834 psi
	P_n	5,680 lbs.
	P_{all}	2,840 lbs.
	stiffeners capacity	2,554
	Max. stiffeners Spacing	31.741 in
<p>Curb is to be continuously supported along the perimeter of curb base and any unit section splits ref. : AISI S100-2016</p>		

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: Retromate

Unit Manufacturer / Model: Aeon RN-006 (AC-4)


Curb Base Hole			
Material Properties			
	F_y		33,000 psi
	F_u		45,000 psi
Base Hole Dimensions			
	Hole Size		0.2500 in
	Fastener Diameter		1/4 in
	Material thickness		14 Ga.
	Curb flange thickness t_f		0.0713 in
	Cut out area		0.05 in ²
	Base flange width		2.0000 in
	Edge distance		0.8750 in
	Base shear area A_n		0.12 in ²
Allowable Screw Capacity			
	Allowable Shear		406 lbs.
	ullout		153 lbs.
Base Hole Forces Short Side Loading			
	Shear	V_s	244 lbs.
	Curb Uplift	T_s	0 lbs.
	$R = \sqrt{T^2 + V^2}$	R_s	244 lbs.
	Min. Hole R/P_{all}		2
Base Hole Forces Long Side Loading			
	Shear	V_L	265 lbs.
	Uplift	T_L	391 lbs.
	$R = \sqrt{T^2 + V^2}$	R_L	472 lbs.
	Min. Hole R/P_{all}		4
Shear Strength AISI Section J6.1			
		V_n	3,369
	Allowable Shear	V_{all}	1,518
		Long	Short
	Min. Hole R/V_{all}	1	1
Base Holes			
		Long	Short
	Min Holes required per side	4	2
	Shear per Hole	66 lbs.	122 lbs.
	Uplift per Hole	98 lbs.	0 lbs.

The screws must be drilled into the existing curb steel at the attachment of the retromate to the existing curb.

As curb manufacturers, Thybar Corporation cannot specify the appropriate attachment hardware for every possible type of roof structure. Thybar provides seismic/wind load calculations that are based on the material provided; typically sheet metal curbs. It is the responsibility of others (project engineer, architect, SEOR, etc) to design a method of the curb attachment to that structure. Thybar does not design the structure and therefore cannot recommend an attachment method that may create difficulties with existing field conditions outside of the curb manufacturer's control.

Unit to Curb Bracket Installation Instructions

- Bracket must be field installed to roof curb before setting unit.
1. Start Bracket 4 inches from end of curb. Then equally distribute Brackets as much as possible while avoiding interferences with lifting lugs, condensate drain lines, unit base screws, Etc.
 2. Screw brackets or Weld at all notches 1 in. long 1/16 in. fillet weld (not for curbs with wood on top) to top of curb.
 3. Gasket top perimeter of curb and brackets before setting unit.



Bracket Quantity per side 2



Max. stiffeners Spacing Curb 31.74 in

Min Base Hole Quantity per side 4 2 0.25

(Holes start 6 in. from base OD)

Thybar Model Restraints	Bracket Qty. Per Unit	Attachment Screws Per Bracket	Product
ACSWRANB0009RC	4	(4) 1/4-14x3 HWH (4) #10-16x1 HWH	for Curb

Total Screws: (16) 1/4-14x3 HWH #1157000
(16) #10-16x1 HWH #1129000



RETROMATE BASE DETAIL

HARDWARE: (QTY. PER CALCULATION) 1/2" TEK SCREWS OR EQUIVALENT AS PROVIDED BY CONTRACTOR (CONTRACTOR TO VERIFY LENGTH REQUIRED)

Meets Requirements for: IBC2018 Seismic Design Category: D
Max. Wind Speed: 97 MPH Building Height: 30 ft.
Exposure Category: B Risk Category: II

City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic



913 S. Kay Avenue
Addison, IL 60101
800-666-CURB (2872)
Fax: 630-543-5309
www.thybar.com



Seismic /97 MPH Wind Load Design Calculations for a

Aeon RN-050 (AC-7,8,9,10,11) on a

**Thybar Retromate
at 1201 39th Ave SW, Puyallup WA 98373**

**Costco 660 - Puyallup, WA
Thybar Order # 215746**

October 27, 2021

This document contains proprietary information from Thybar Corporation. Its contents may not be used for any other project or location other than the project or location for which it was created without the prior written permission of Thybar Corporation.

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW, Puyallup WA 98373

Seismic Design Category: D

Summary

Assumptions

Review all pages prior to installing

1. These calculations begin with the assumption that the Thybar Retromates is supported around its full perimeter by the existing curb.
2. The Thybar Retromate must be attached to the existing curb using welds or bolts at the Retromate base flanges. The existing curb is assumed to be of sufficient structural integrity to withstand all seismic and wind load forces transmitted to it by the Retromate. Thybar Corporation is not responsible for verification of existing curb structural integrity and verification of building structure supporting the existing and new adapter curb is not the responsibility of Thybar Corporation.
3. As curb manufacturers, Thybar Corporation cannot be expected to provide appropriate attachment hardware for every possible type of roof structure. Thybar provides seismic/wind load calculations that are based on the material provided; typically sheet metal curbs. It is the responsibility of others (project engineer, architect, SEOR, etc.) to know enough about the load carrying capability of the building structure to design a method of attachment to that structure. Thybar does not design the structure and therefore should not recommend an attachment method that may create difficulties with existing field conditions outside of the curb manufacturer's control.

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW, Puyallup WA 98373

Seismic Design Category: D

Equipment			
Manufacturer	Aeon		
Unit Model	RN-050 (AC-7,8,9,10,11)		
Base Length	153 in	CG _{x1}	88.10 in
Base Width	99 3/4 in	CG _{y1}	50.75 in
Height	101 3/4 in	Top Area A _t	126.9 ft ²
Unit Weight	6,419 lbs.	Long Side Area	111.3 ft ²
Total Operating Weight	6,419 lbs.	Short Side Area	70.5 ft ²

Thybar Product							
Product	Insulated Roof Curb No Top Nailer					1	
Length OD	148 3/4 in	Width OD	95 7/8 in	Min. Height	10.00 in	Max. Height	10.00 in
Material	12 Ga. Prime Galv Steel		Thickness	0.1017 in	Est. Weight		392 lbs.
Poisson's Ratio ν	0.297		Yield Strength F _y	33,000 psi		Flat height of	curb wall h
Tensile Strength F _u	45,000 psi		Young's Modulus E	29,000,000 psi		9.59 in	

Diagram Dimensions: 148 3/4 in (width), 95 7/8 in (height)

Corner 2 Height: 10.000 in

Corner 3 Height: 10.000 in

Corner 1 Height: 10.000 in

Corner 4 Height: 10.000 in

Return End

Wind Load Factors		Seismic Load Factors	
Exposure Category	B	Site Soil Classification	D
Height for Wind Calculations	30.0 ft.	Occupancy/Risk Category	II
Wind Speed V	97 MPH	S _s (% of g)	126.70%
Velocity Pressure coefficient K _z	0.70	S ₁ (% of g)	43.70%
Topography factor K _{zt}	1.00	S _{DS}	1.014
Directionality factor K _d	0.85	S _{D1}	0.000
qh	14.14	F _a	1.20
Importance factor I _w	N/A	F _v	0.00
GCr	1.90	Snow Load	
GC (Uplift)	1.50	C _t	1.1
Ke	0.99	C _E	1
		Snow Importance, I	1.0
		Unit Roof Snow Load	11.6 lb/ft ²

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: Retromate

Unit Manufacturer / Model: Aeon RN-050 (AC-7,8,9,10,11)

Unit Forces		
Unit Height	H	101.75 in
Unit COG	CG _y	50.75 in
Unit COG	CG _x	88.10 in
Unit COG	CG _z	50.88 in
Total Operating Weight	W _u	6,419 lbs.
Weight Long Side	W _{ul}	3,903 lbs.
Weight Short Side	W _{us}	2,516 lbs.
Snow Load	SL	1,466 lbs.
Snow Long Side	SL _l	892 lbs.
Snow Short Side	SL _s	575 lbs.
Wind Load (97 mph) Long Side	F _{wu}	2,988 lbs.
Wind Load (97 mph) Short Side	F _{wu}	1,893 lbs.
Wind Upward Force	F _{up}	2,692 lbs.
Seismic Force	F _{eu}	3,254 lbs.
	F _{eu Max}	10,414 lbs.
	F _{eu Min}	1,953 lbs.
Seismic Vertical ± Force	F _{upu}	1,302 lbs.
	z / h	1.0

Long Side Loading	Short Side Loading

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: Retromate

Unit Manufacturer / Model: Aeon RN-050 (AC-7,8,9,10,11)

Curb Forces				Maximum Total Loading on Bracket			
Curb Max Height	h	10.00 in		Uplift Long Side	0.6D+0.7E	Pw	232 lbs.
Centerline Width	w	97.88 in		Shear Long Side	0.6D+0.7E	Sw	1,139 lbs.
Curb Weight	W _c	392 lbs.		Uplift Short Side	0.6D+0.7E	Ps	-67 lbs.
Wind Load (97 mph) Long Side	F _{wc}	277 lbs.		Shear Short Side	0.6D+0.7E	Ss	1,139 lbs.
Wind Load (97 mph) Short Side	F _{wc}	179 lbs.		Maximum Load at Curb			
Seismic Force	F _{ec}	199 lbs.		Axial Load Long	D+0.75(0.7E)+0.75S	Twc	5,552 lbs.
	F _{ec Max}	635 lbs.		Shear Long	D+0.7E	Swc	1,139 lbs.
	F _{ec Min}	119 lbs.		Axial Load Short	D+0.75(0.7E)+0.75S	Tsc	5,778 lbs.
Curb Seismic Vertical ± Force	F _{upc}	79 lbs.		Shear Short	D+0.7E	Ssc	1,139 lbs.
				Maximum Load at Curb Base			
				Uplift Long Side	0.6D+0.7E	Pwb	407 lbs.
				Shear Long Side	0.6D+0.7E	Swb	1,208 lbs.
				Uplift Short Side	0.6D+0.7E	Psb	31 lbs.
				Shear Short Side	0.6D+0.7E	Ssb	1,208 lbs.
Long Side Loading				Short Side Loading			

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018


Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: Retromate

Unit Manufacturer / Model: Aaon RN-050 (AC-7,8,9,10,11)

Unit to Curb Bracket Design			
Unit and Curb		Screw Capacity @ Side of Bracket	
	Long	Short	
Unit Shear	1,139 lbs.	1,139 lbs.	Screw size/type (#)
Unit Uplift	232 lbs.	0 lbs.	Hole size
Curb Length/Width	148.75 in	95.88 in	Allowable pullout/screw
			Allowable shear/screw
Bracket Dimensions		Long	Short
Length L	8.00 in	Tension on Screws	1,139 lbs. 569 lbs.
Max bending arm BA	1.72 in	Shear on Screws	232 lbs. 0 lbs.
Gauge	10 Ga	# Screws for pullout/Bracket	4
thickness t	0.1220 in	# Screws for Shear/Bracket	4
Yield Strength F_y	50,000 psi	Combined loading check $I_f < 1$ Ok	0.359
Cross Sectional Area	0.98 in ²	Screw Capacity @ Top of Bracket	
Bracket Flexure Capacity		Screw size/type (#)	10
F_y	50,000 psi	Hole size	0.25 in
Allowable Uplift T_a	519 lbs.	Allowable pullout/screw	182 lbs.
		Allowable shear/screw	404 lbs.
Bracket Quantity		Long	Short
	Long	Short	
Brackets Required, # per side	2	0	Tension on Screws T_c
Total Brackets Required	4		Shear on Screws
			# Screws for pullout/Bracket
			# Screws for Shear/Bracket
			Combined loading check $I_f < 1$ Ok
			0.150
			Bracket Shear Capacity at Holes
			Max Shear / Bracket
			hole edge to bracket edge e
			Allowable shear stress F_v
			Allowable shear / Bracket P_s



Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: Retromate

Unit Manufacturer / Model: Aaon RN-050 (AC-7,8,9,10,11)

Curb Wall Design		
Compression of Curb Wall		
	K	4
	f_{cr}	764 psi
	F_a	382 psi
Material thickness	t	0.102 in
	P	1,926 lbs.
stiffeners Required	b	37.64
	OK f_a	382 psi
	OK Lc/ts	94
Shear on Short Side of Curb Wall		
	α	9.99
	K_s	5.38
	f_{cr}	15,817 psi
	F_v	7,908 psi
	f_v	58 psi
stiffeners Design		
stiffeners Width	ws	1.00 in
stiffeners Thickness	ts	0.102 in
stiffeners Length	Lc	9.593 in
	ws/ts	9.83
$0.42\sqrt{E/F_y}$		12.45
	weff	1.000 in
Bearing Stiffener Capacity per AISI F5.1 (a)		
	As	0.10 in ²
	Ac	0.29 in ²
	Pn	9,500 lbs.
	Pall	4,750 lbs.
Bearing Stiffener Capacity per AISI F5.1 (b)		
	Ab	0.35 in ²
	Fe	259,173 psi
	Fn	31,287 psi
	Pn	10,838 lbs.
	Pall	5,419 lbs.
	stiffeners capacity	4,750
Max. stiffeners Spacing		37.640 in
<p>Curb is to be continuously supported along the perimeter of curb base and any unit section splits ref. : AISI S100-2016</p>		

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: Retromate

Unit Manufacturer / Model: Aeon RN-050 (AC-7,8,9,10,11)

Curb Base Hole			
Material Properties			
	F_y		33,000 psi
	F_u		45,000 psi
Base Hole Dimensions			
	Hole Size		0.2500 in
	Fastener Diameter		1/4 in
	Material thickness		12 Ga
	Curb flange thickness t_f		0.1017 in
	Cut out area		0.05 in ²
	Base flange width		2.0000 in
	Edge distance		0.8750 in
	Base shear area A_n		0.18 in ²
Allowable Screw Capacity			
	Allowable Shear		406 lbs.
	ullout		153 lbs.
Base Hole Forces Short Side Loading			
	Shear	V_s	1,208 lbs.
	Curb Uplift	T_s	31 lbs.
	$R = \sqrt{T^2 + V^2}$	R_s	1,209 lbs.
	Min. Hole R/P_{all}		8
Base Hole Forces Long Side Loading			
	Shear	V_L	1,208 lbs.
	Uplift	T_L	407 lbs.
	$R = \sqrt{T^2 + V^2}$	R_L	1,275 lbs.
	Min. Hole R/P_{all}		9
Shear Strength AISI Section J6.1			
		V_n	4,805
	Allowable Shear	V_{all}	2,165
		Long	Short
	Min. Hole R/V_{all}	1	1
Base Holes			
		Long	Short
	Min Holes required per side	9	8
	Shear per Hole	134 lbs.	151 lbs.
	Uplift per Hole	45 lbs.	4 lbs.




The screws must be drilled into the existing curb steel at the attachment of the retromate to the existing curb.

As curb manufacturers, Thybar Corporation cannot specify the appropriate attachment hardware for every possible type of roof structure. Thybar provides seismic/wind load calculations that are based on the material provided; typically sheet metal curbs. It is the responsibility of others (project engineer, architect, SEOR, etc) to design a method of the curb attachment to that structure. Thybar does not design the structure and therefore cannot recommend an attachment method that may create difficulties with existing field conditions outside of the curb manufacturer's control.

Thybar Model Restraints	Bracket Qty. Per Unit	Attachment Screws Per Bracket	Product
ACSWRANB0027RC	4	(4) 1/4-14x3 HWH (4) #10-16x1 HWH	for Curb

Unit to Curb Bracket Installation Instructions
Bracket must be field installed to roof curb before setting unit.
1. Start Bracket 4 inches from end of curb. Then equally distribute Brackets as much as possible while avoiding interferences with lifting lugs, condensate drain lines, unit base screws, Etc.
2. Screw brackets or Weld at all notches 1 in. long 1/16 in. fillet weld (not for curbs with wood on top) to top of curb.
3. Gasket top perimeter of curb and brackets before setting unit.

Total Screws: (16) 1/4-14x3 HWH #1157000
(16) #10-16x1 HWH #1129000



Requires 1/2 in. Thick Gasket
VERIFY ALL ELECTRICAL WIRES ARE CLEAR OF BASE RAIL INTERIOR BEFORE INSTALLING RESTRAINT

RETROMATE BASE DETAIL
HARDWARE: (QTY. PER CALCULATION) 3/8" TEK SCREWS OR EQUIVALENT AS PROVIDED BY CONTRACTOR (CONTRACTOR TO VERIFY LENGTH REQUIRED)

Max. stiffeners Spacing Curb 37.64 in
Min Base Hole Quantity per side 9 8 0.25

<p>The information contained in this drawing is the sole property of Thybar Corporation. Any reproduction in part or whole without the written consent of Thybar Corporation is prohibited.</p> <p>Requires 1/2 in. Thick Gasket</p>		<p>Seismic / Wind load Restraint for Aaon RN-050 On a Thybar Retromate with Top Duct Supports Costco 660 - Puyallup, WA 1201 39th Ave SW, Puyallup WA 98373</p>
<p>(DO NOT SCALE DRAWING) Unless otherwise specified dimensions are in inches tolerances are ± 1/16 ± 1°</p>		<p>Qty: 1 Job# 215746 Tag: (AC-7,8,9,10,11) Drawing is conceptual, not to scale Page 9 of 9 2.15746-3</p>
<p>Seismic & Wind load Restraints are designed & calculated for use in Seismic & Wind load applications when provided as part of a Seismic & Wind load rated Thybar curb. Attachment of calculated Restraint to any other curb does not constitute a Seismic & Wind load rated assembly. Thybar Corporation has a policy of continuous product improvement and reserves the right to change the product design without notice.</p>		<p>Meets Requirements for: IBC2018 Seismic Design Category: D Max. Wind Speed: 97 MPH Building Height: 30 ft. Exposure Category: B Risk Category: II</p>
<p>(Holes start 6 in. from base OD) Long Short Hole Size</p>		<p>thybar CORPORATION <i>Thybar makes it right the first time, every time.</i></p>



913 S. Kay Avenue
Addison, IL 60101
800-666-CURB (2872)
Fax: 630-543-5309
www.thybar.com



Seismic /97 MPH Wind Load Design Calculations for a

LG LUU369HV (CU-2) on a

**Thybar Retromate
at 1201 39th Ave SW, Puyallup WA 98373**

**Costco 660 - Puyallup, WA
Thybar Order # 215746**

October 28, 2021

This document contains proprietary information from Thybar Corporation. Its contents may not be used for any other project or location other than the project or location for which it was created without the prior written permission of Thybar Corporation.

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW, Puyallup WA 98373

Seismic Design Category: D

Summary

Assumptions

Review all pages prior to installing

1. These calculations begin with the assumption that the Thybar Retromates is supported around its full perimeter by the existing curb.
2. The Thybar Retromate must be attached to the existing curb using welds or bolts at the Retromate base flanges. The existing curb is assumed to be of sufficient structural integrity to withstand all seismic and wind load forces transmitted to it by the Retromate. Thybar Corporation is not responsible for verification of existing curb structural integrity and verification of building structure supporting the existing and new adapter curb is not the responsibility of Thybar Corporation.
3. As curb manufacturers, Thybar Corporation cannot be expected to provide appropriate attachment hardware for every possible type of roof structure. Thybar provides seismic/wind load calculations that are based on the material provided; typically sheet metal curbs. It is the responsibility of others (project engineer, architect, SEOR, etc.) to know enough about the load carrying capability of the building structure to design a method of attachment to that structure. Thybar does not design the structure and therefore should not recommend an attachment method that may create difficulties with existing field conditions outside of the curb manufacturer's control.

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA


Applicable Building Code: IBC2018

Location: 1201 39th Ave SW, Puyallup WA 98373

Seismic Design Category: D

Equipment			
Manufacturer	LG		
Unit Model	LUU369HV (CU-2)		
Base Length	24 3/8 in	CG _{x1}	14.64 in
Base Width	14 3/16 in	CG _{y1}	8.51 in
Height	54 3/8 in	Top Area A _t	3.7 ft ²
Unit Weight	199 lbs.	Long Side Area	14.1 ft ²
Total Operating Weight	199 lbs.	Short Side Area	5.4 ft ²

Thybar Product							
Product	TEMS3 Short Side				TEMS Qty.	2	
TEMS Length	44 1/2 in	TEMS Offset	24 7/16 in	Min. Height	3.00 in	Max. Height	3.00 in
Material	14 Ga. Prime Galv Steel		Thickness	0.0713 in	Est. Weight	62 lbs.	
Poisson's Ratio ν	0.297		Yield Strength F _y	33,000 psi	Flat height of curb wall h	2.71 in	
Tensile Strength F _u	45,000 psi		Young's Modulus E	29,000,000 psi			



Wind Load Factors		Seismic Load Factors	
Exposure Category	B	Site Soil Classification	D
Height for Wind Calculations	30.0 ft.	Occupancy/Risk Category	II
Wind Speed V	97 MPH	S _s (% of g)	126.70%
		S ₁ (% of g)	43.70%
Velocity Pressure coefficient K _z	0.70	S _{DS}	1.014
Topography factor K _{zt}	1.00	a _p	2.50
Directionality factor K _d	0.85	I _p	1.00
qh	14.14	R _p	6.00
Importance factor I _w	N/A		
GCr	1.90	Snow Load	
GC (Uplift)	1.50	C _t	1.1
Ke	0.99	C _E	1
		Snow Importance, I	1.0
		Unit Roof Snow Load	11.6 lb/ft ²

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW

Seismic Design Category: D

Puyallup, WA 98373

Curb Type: Retromate

Unit Manufacturer / Model: LG LUU369HV (CU-2)

Unit Forces		
Unit Height	H	54.34 in
Unit COG	CG_y	8.51 in
Unit COG	CG_x	14.64 in
Unit COG	CG_z	27.19 in
Total Operating Weight	W_u	199 lbs.
Weight Long Side	W_{ul}	199 lbs.
Weight Short Side	W_{us}	199 lbs.
Snow Load	SL	42 lbs.
Snow Long Side	SL_l	42 lbs.
Snow Short Side	SL_s	42 lbs.
Wind Load (97 mph) Long Side	F_{wu}	379 lbs.
Wind Load (97 mph) Short Side	F_{wu}	144 lbs.
Wind Upward Force	F_{up}	78 lbs.
Seismic Force	F_{eu}	101 lbs.
	$F_{eu} \text{ Max}$	323 lbs.
	$F_{eu} \text{ Min}$	61 lbs.
Seismic Vertical \pm Force	F_{upu}	40 lbs.
	z/h	1.0

Long Side Loading	Short Side Loading

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: TEMS3 Short Side

Unit Manufacturer / Model: LG LUU369HV (CU-2)

TEMS Forces				Maximum Total Loading on Screw			
TEMS Max Height	h	3.00 in	Uplift Long Side	$0.6D+0.6W$	P_w	411 lbs.	
Centerline Width	w	14.19 in	Shear Long Side	$0.6D+0.6W$	S_w	227 lbs.	
TEMS Weight	W_c	62 lbs.	Uplift Short Side	$0.6D+0.6W$	P_s	70 lbs.	
Wind Load (97 mph) Long Side	F_{wc}	2 lbs.	Shear Short Side	$0.6D+0.6W$	S_s	86 lbs.	
Wind Load (97 mph) Short Side	F_{wc}	25 lbs.	Maximum Load at TEMS				
Seismic Force	F_{ec}	31 lbs.	Axial Load Long	$D+0.6W$	T_w	531 lbs.	
	$F_{ec Max}$	101 lbs.	Shear Long	$D+0.6W$	S_w	227 lbs.	
	$F_{ec Min}$	19 lbs.	Axial Load Short	$D+0.7E$	T_s	270 lbs.	
TEMS Seismic Vertical \pm Force	F_{upc}	13 lbs.	Shear Short	$D+0.6W$	S_s	86 lbs.	
				Maximum Load at TEMS Base			
				Uplift Long Side	$0.6D+0.6W$	P_w	85 lbs.
				Shear Long Side	$0.6D+0.6W$	S_w	230 lbs.
				Uplift Short Side	$0.6D+0.6W$	P_s	38 lbs.
				Shear Short Side	$0.6D+0.6W$	S_s	116 lbs.
Long Side Loading				Short Side Loading			

Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018


Location: 1201 39th Ave SW
 Puyallup, WA 98373

Seismic Design Category: D

Curb Type: TEMS3 Short Side

Unit Manufacturer / Model: LG LUU369HV (CU-2)

Unit to TEMS Screw Design				
Unit and TEMS			Screw Capacity	
	Long	Short		
Unit Shear	227 lbs.	86 lbs.	Screw size/type (#)	1/4 304 SS
Unit Uplift	411 lbs.	70 lbs.	Hole size	0.25 in
TEMS Length and Offset	44.50 in	24.44 in	Allowable pullout/screw	1400 lbs.
			Allowable shear/screw	746 lbs.
			Long	
			Tension on Screws	411 lbs.
			Shear on Screws	114 lbs.
			# Screws for pullout/Bracket	2
			# Screws for Shear/Bracket	2
			Combined loading check $I_f < 1$ Ok	0.223



Thybar Corporation Seismic /Wind Load Design Calculations for Order # 215746

Job Name: Costco 660 - Puyallup, WA

Applicable Building Code: IBC2018

Location: 1201 39th Ave SW
Puyallup, WA 98373

Seismic Design Category: D

Curb Type: TEMS3 Short Side

Unit Manufacturer / Model: LG LUU369HV (CU-2)



TEMS Base Hole	
Material Properties	
F _y	33,000 psi
F _u	45,000 psi
Base Hole Dimensions	
Hole Size	0.6250 in
Fastener Diameter	1/2 in
Material thickness	14 Ga.
TEMS flange thickness t _f	0.1426 in
Cut out area	0.31 in ²
Base flange width	2.0000 in
Edge distance	0.6875 in
Base shear area A _n	0.20 in ²
Bearing strength w/o bolt hole deformation AISI Section J3.3.1	
P _n	7,219 lbs.
Allowable Bearing P _{all}	2,888 lbs.
TEMS Base Hole Forces Short Side Loading	
Shear V _s	58 lbs.
Uplift T _s	58 lbs.
$R = \sqrt{T^2 + V^2}$ R _s	82 lbs.
Min. Holes per TEMS side R/Pall	2
TEMS Base Hole Forces Long Side Loading	
Shear V _L	29 lbs.
Uplift T _L	18 lbs.
$R = \sqrt{T^2 + V^2}$ R _L	34 lbs.
if R/Pall is < 1 number of holes OK	0.01
Shear Strength AISI Section J6.1	
V _n	5,294
Allowable Shear V _{all}	2,385
	LS Loading SS Loading
Min. Holes per TEMS side R/V _{all}	1 1
Base Holes	
Min. Holes per TEMS Long Side	2
Shear per Hole	14 lbs.
Uplift per Hole	9 lbs.
<p>As curb manufacturers, Thybar Corporation cannot specify the appropriate attachment hardware for every possible type of roof structure. Thybar provides seismic/wind load calculations that are based on the material provided; typically sheet metal curbs. It is the responsibility of others (project engineer, architect, SEOR, etc) to design a method of the TEMS attachment to that structure. Thybar does not design the structure and therefore cannot recommend an attachment method that may create difficulties with existing field conditions outside of the curb manufacturer's control.</p>	

Use screws at 18" min.:
Long Side = 6
Short Side = 4

The screws must be drilled into the existing curb steel at the attachment of the retromate to the existing curb.

Thybar Model Restraints	Bolt Qty. Per Unit	Attachment Screws	Product
N/A	4	(4) 1/4" Dia. 304 SS Bolts with Nuts	

Unit to Curb Screw Installation Instructions
1. Units directly connected to the top of Terms at specified unit location



VERIFY ALL ELECTRICAL WIRES ARE CLEAR OF BASE RAIL INTERIOR BEFORE INSTALLING RESTRAINT

Min Base Hole Quantity per side	6	4	0.25
---------------------------------	---	---	------

<p>Seismic / Wind load Restraint for LG LUU369HV On a Thybar Retromate with Equipment Bases Costco 660 - Puyallup, WA 1201 39th Ave SW, Puyallup WA 98373</p>		<p>Qty: 1 Job# 215746 Tag: (CU-2) Drawing is conceptual, not to scale Page 8 of 8</p>
<p>The information contained in this drawing is the sole property of Thybar Corporation. Any reproduction in part or whole without the written consent of Thybar Corporation is prohibited.</p>		<p>(DO NOT SCALE DRAWING) Unless otherwise specified dimensions are in inches tolerances are ± 1/16 ± 1° Date 10/28/2021</p>
<p>(Holes start 6 in. from base OD) Long Short Hole Size</p>		
<p>Meets Requirements for: IBC2018 Seismic Design Category: D Max. Wind Speed: 97 MPH Building Height: 30 ft. Exposure Category: B Risk Category: II</p>		
<p>Seismic & Wind load Restraints are designed & calculated for use in Seismic & Wind load applications when provided as part of a Seismic & Wind load rated Thybar curb. Attachment of calculated Restraint to any other curb does not constitute a Seismic & Wind load rated assembly. Thybar Corporation has a policy of continuous product improvement and reserves the right to change the product design without notice.</p>		

