

COSTCO WHOLESale

1201 39th Avenue SW
Puyallup, WA

STRUCTURAL CALCULATIONS FOR HVAC REMODEL

THE APPROVED CONSTRUCTION PLANS AND ALL ENGINEERING DOCUMENTS MUST BE POSTED ON THE JOB AT ALL INSPECTIONS IN A VISIBLE AND READILY ACCESSIBLE LOCATION.



2018 International Building Code
December 21, 2021
ENW #99090013

B-21-0421

ENW ENGINEERS NORTHWEST, INC., P.S. ~ STRUCTURAL ENGINEERS

9725 THIRD AVE NE, SUITE 207, SEATTLE, WA 98115 (206) 525-7560 FAX (206) 522-6698

PROJECT # 99090013 PROJECT C. PUYALUP, WA. DATE 3/31/2021
 SUBJECT HVAC REPLACEMENT SHEET OF
 BY RZ

• DESCRIPTIONS: REPLACE EXISTING HVAC UNIT

• CODE: 2018 IBC

• EXISTING LOADS: $LL = 25 \text{ PSF}$
 $DL = 12 \text{ PSF}$
 $27 \text{ PSF} \times 5' = 135 \text{ PLF}$
 USE 192 PLF FROM SPAN DRAWING

NEW LOADS: $LL = 25 \text{ PSF}$
 $DL = 10 \text{ PSF}$ (MINUS 2 PSF MECHANICAL WEIGHT)

	(E) WEIGHT	NEW WEIGHT		
AC-1	835#	350#	7'	31'
AC-2	1093	350#		
			22'	36'
AC-4	1342	1866#	EXISTING DESIGN	
			1800#	
AC-5	748	350#	1866	$66/1800 = 3.6\%$
			9'	43' < 5% OK.

B-21-0421

ENW ENGINEERS NORTHWEST, INC., P.S. ~ STRUCTURAL ENGINEERS

9725 THIRD AVE NE, SUITE 207, SEATTLE, WA 98115 (206) 525-7560 FAX (206) 522-6698

PROJECT # _____ PROJECT _____ DATE _____
 SUBJECT _____ SHEET _____ OF _____
 By _____

AC-6. (E) 748 (W) 350# 22' 36'

AC-7.11. 8300# 8181
 8.9.10. 4 3 17' 36'
 2075 2727. < 3900# OK.

ORIGINAL DESIGN. LOAD.

~~AC-12. NEW UNIT. 3701#.~~
~~3701 / 3 / 2 = 617#.~~
 5' 36'
 420x6 = 2520# MAX
 N. G.
 GIRDER AND COL. OK.

(New) 12-21/21


HVAC EQUIPMENT SCHEDULE-S.O.I.C.

SYMBOL	TECH	SERVICES	MFR / #	DESCRIPTION	ELECT.	FAN HP	REFERENCE	REMARKS	NOTES	MFR / #	HEAT	ELECTRICAL (V/A)	EXISTING UNIT DATA		STRUCTURAL VERIFICATION		REMARKS
													NET WEIGHTS	NEW NET WEIGHTS	NEW UNIT WEIGHTS	NEW UNIT WEIGHTS	
AH-1	SPLIT SYSTEM UNIT	PHARMACY	LG LVA361HVA	3 TON MULTI POSITION AIR HANDLING UNIT: HEAT PUMP LIQUID LINE: 3/8" GAS LINE OD: 5/8"	208V/1# 40 MCOP 32 MCA		PLAN ME-1 71/ME	AIR TRANSFERRED FROM MAIN SALES O/A FROM MAIN SALES UNITS	(72)	TRANE YCC03030A LOBA	NATURAL GAS 40 MBH	208V/1# 15 MCOP 25 MCA	128# UNIT	128# UNIT	NEW UNIT MOUNTED INDOOR SUSPENDED FROM STRUCTURE	NEW UNIT WEIGHTS 485# LESS THAN EXISTING CONDITION	
CU-1	SPLIT SYSTEM UNIT	PHARMACY	LG LUU369HV	3 TON MINI SPLIT SYSTEM CONDENSING UNIT SEER = 18, HSPF = 10	208V/1# 40 MCOP 32 MCA		PLAN ME-1 70/ME		(58)			208V/1# 15 MCOP 25 MCA	150# DESIGN 200# UNIT 50# CURB 100# TOTAL	150# DESIGN 200# UNIT 50# CURB 100# TOTAL	NEW UNIT WEIGHTS 485# LESS THAN EXISTING CONDITION		
AH-2	SPLIT SYSTEM UNIT	OFFICE	LG LVA361HVA	3 TON MULTI POSITION AIR HANDLING UNIT: HEAT PUMP LIQUID LINE: 3/8" GAS LINE OD: 5/8"	208V/1# 40 MCOP 32 MCA		PLAN ME-1 71/ME	AIR TRANSFERRED FROM MAIN SALES O/A FROM MAIN SALES UNITS	(72)	TRANE YCC03030A LOBA	NATURAL GAS 40 MBH	208V/1# 15 MCOP 25 MCA	128# UNIT	128# UNIT	NEW UNIT MOUNTED INDOOR SUSPENDED FROM STRUCTURE	NEW UNIT WEIGHTS 485# LESS THAN EXISTING CONDITION	
CU-2	SPLIT SYSTEM UNIT	OFFICE	LG LUU369HV	3 TON MINI SPLIT SYSTEM CONDENSING UNIT SEER = 18, HSPF = 10	208V/1# 40 MCOP 32 MCA		PLAN ME-1 70/ME		(58)			208V/1# 15 MCOP 25 MCA	150# DESIGN 200# UNIT 50# CURB 100# TOTAL	150# DESIGN 200# UNIT 50# CURB 100# TOTAL	NEW UNIT WEIGHTS 485# LESS THAN EXISTING CONDITION		
AC-4	AIR CONDITIONER	TIRE SALES	MAON RN-008-30 BB02-222	67 MBH TOTAL COOLING, 48 MBH SENSIBLE, 82.2F AMB, 77.5F EDB, 65.2 F EWB, 2400 CFM @ 0.5" ESP, SEER = 14.3, 80 MBH INPUT, 72.5MBH OUTPUT, 81% AFUE	460V/3# 20 MCOP 13 FLA		PLAN ME-1 60/ME	500 CFM MIN O/A SINGLE ZONE VAV	(4) (55)(57) (64)(77)	TRANE YC007504 LOBA	NATURAL GAS 120 MBH	460V/3# 25 MCOP 17.7 MCA	90# UNIT 18# CURB 108# TOTAL	90# UNIT 18# CURB 108# TOTAL	NEW UNIT WEIGHTS 524# MORE THAN EXISTING CONDITION		
AH-5	SPLIT SYSTEM UNIT	OPTICAL	LG LVA241HVA	2 TON MULTI POSITION AIR HANDLING UNIT: HEAT PUMP LIQUID LINE: 3/8" GAS LINE OD: 5/8"			PLAN ME-1 71/ME	AIR TRANSFERRED FROM MAIN SALES O/A FROM MAIN SALES UNITS	(72)				129# UNIT	129# UNIT	NEW UNIT MOUNTED INDOOR SUSPENDED FROM STRUCTURE	NEW UNIT WEIGHTS 485# LESS THAN EXISTING CONDITION	
CU-5	SPLIT SYSTEM UNIT	OPTICAL	LG LUU249HV	2 TON MINI SPLIT SYSTEM CONDENSING UNIT SEER = 19.5, HSPF = 11	208V/1# 30 MCOP 20 MCA		PLAN ME-1 70/ME		(58)	TRANE YCC018F1 LOBA	NATURAL GAS 40 MBH	208V/1# 13 MCA	150# DESIGN 200# UNIT 50# CURB 350# TOTAL	150# DESIGN 200# UNIT 50# CURB 350# TOTAL	NEW UNIT WEIGHTS 398# LESS THAN EXISTING CONDITION		
AH-6	SPLIT SYSTEM UNIT	EDP	LG LVA241HVA	2 TON MULTI POSITION AIR HANDLING UNIT: HEAT PUMP LIQUID LINE: 3/8" GAS LINE OD: 5/8"			PLAN ME-1 71/ME	AIR TRANSFERRED FROM MAIN SALES O/A FROM MAIN SALES UNITS	(72)				129# UNIT	129# UNIT	NEW UNIT MOUNTED INDOOR SUSPENDED FROM STRUCTURE	NEW UNIT WEIGHTS 485# LESS THAN EXISTING CONDITION	
CU-6	SPLIT SYSTEM UNIT	EDP	LG LUU249HV	2 TON MINI SPLIT SYSTEM CONDENSING UNIT SEER = 19.5, HSPF = 11	208V/1# 30 MCOP 20 MCA		PLAN ME-1 70/ME		(58)	TRANE YCC018F1 LOBA	NATURAL GAS 40 MBH	208V/1# 13.2 MCA	150# DESIGN 200# UNIT 50# CURB 350# TOTAL	150# DESIGN 200# UNIT 50# CURB 350# TOTAL	NEW UNIT WEIGHTS 398# LESS THAN EXISTING CONDITION		
AC-7,11	AIR CONDITIONER	MAIN SALES HIGH HEAT	MAON RR-050-30 B004-262	531 MBH TOTAL COOLING, 413 MBH SENSIBLE, 82.2F AMB, 78.0F EDB, 61.0 F EWB, 18500 CFM @ 0.5" ESP, SEER = 10.6, 540 MBH INPUT, 437.4MBH OUTPUT, 81% AFUE	460V/3# 125 MCOP 119 MCA		PLAN ME-1 60/ME	MIN 2000 CFM O/A UP TO 3500 CFM BASED ON CO2 LEVELS	(6) (55)(60) (77)(78)	TRANE YC0600A4 LA1A14DD1B	NATURAL GAS 400 MBH	460V/3# 136 MCA	6230# NEW UNIT 365# CURB 786# ADAPTER 8330# TOTAL	6230# NEW UNIT 365# CURB 786# ADAPTER 8330# TOTAL	NEW UNIT WEIGHTS 118# LESS THAN EXISTING CONDITION		
AC-8,9,10	AIR CONDITIONER	MAIN SALES HIGH HEAT	MAON RR-050-30 B004-262	531 MBH TOTAL COOLING, 413 MBH SENSIBLE, 82.2F AMB, 78.0F EDB, 61.0 F EWB, 18500 CFM @ 0.5" ESP, SEER = 10.6, 540 MBH INPUT, 437.4MBH OUTPUT, 81% AFUE	460V/3# 125 MCOP 119 MCA		PLAN ME-1 60/ME	MIN 2000 CFM O/A UP TO 3500 CFM BASED ON CO2 LEVELS	(6) (55)(60) (78)	TRANE YC0600A4 LA1A14DD1B	NATURAL GAS 400 MBH	460V/3# 136 MCA	6230# NEW UNIT 365# CURB 786# ADAPTER 8330# TOTAL	6230# NEW UNIT 365# CURB 786# ADAPTER 8330# TOTAL	NEW UNIT WEIGHTS 118# LESS THAN EXISTING CONDITION		

City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic

COPY OF EXISTING DRAWING



ALL STRUT JOIST DESIGNED FOR 33 KIPS BOTTOM CHORD AXIAL LOAD.

⑥

DESIGN LOADS:

- LIVE LOAD = 25 PSF (LIVE LOAD)
- DEAD LOAD = 1.5 PSF (ROOF)
- DEAD LOAD = 2.5 PSF (JOIST & BRIDGING BY SMI)
- COLLATERAL LOAD = 8.0 PSF OR (6.5 + SPRINKLER LOAD)
- GROSS WIND UPLIFT = 26.3 PSF (TYP. U.N.O.)
- GROSS WIND UPLIFT = 46.3 PSF (AT 10'-0" EDGE ZONES)
- NET WIND UPLIFT = 23.3 PSF (TYP. U.N.O.)
- NET WIND UPLIFT = 43.3 PSF (AT 10'-0" EDGE ZONES)

"INCREASE ALL DESIGN LOADS BY 1.5%."

⑦

DESIGN NOTES:

NET UPLIFT = -119 PLF

TOP CHORDS ARE Laterally supported BY THE DECK FOR DEAD PLUS LIVE LOADS ONLY.

TOP CHORDS ARE UNSUPPORTED IN UPLIFT CONDITIONS ONLY.

1/3 STRESS INCREASE IN WIND & SEISMIC STRESSES ALLOWED.

DEFLECTION = L/240

JOIST PANELS TO ALIGN PER BAY.

HOLD DEFAULT END PANELS FOR NON-STRUT JOIST FOR BCX LENGTH.

ALL JOIST ARE 24" DEEP.

ALL JOIST SEATS TO BE 2 1/2" DEEP, 4" LONG, AND BOLTED.(U.N.O.)

NO BOLTING @ SKEWED FRAME, WELD SEATS.

ALL SEAT SLOTS TO BE 9/16" x 2" LONG W/3 1/4" GAUGE.

ALL BRIDGING IS TO BE BOLTED.(OR FIELD WELDED AS NEEDED)

⑧

JOIST LOADING:


UNITS = PLF

TOTAL LOAD/LIVE LOAD/UPLIFT

TYPICAL JOIST TYPE IS,

24KS192/127/-119

COPY OF EXISTING DRAWING



SPECIAL DRAWING NOTES:

- [] = 100% STRESS REVERSAL
- [] = MINIMUM BOTTOM CHORD MATERIAL = 2.5" x 2.5" x .25" NO FILLS WITHIN 1'-0" FROM END OF BOTTOM.

SPECIAL JOIST LOADS:

No.	Qty	I/B	Type	Dir	Load1	Dist1	Load2	Dist2	Ref	Remarks
1	CL	T	CanV	Y	3800				L	(2;1850#) RTU
2	EL	B	Chd	X	33000				L	STRUT
	WL	B	Chd	Y	31100				L	STRUT
3	DL	T	Uni	Y	35		35		L	8" PIPE
4	DL	T	Uni	Y	70		70		L	8"+8" PIPE
5	DL	T	Uni	Y	22		22		L	8" PIPE
6	CL	T	CanV	Y	2080				L	(4;520#) PIPE
7	CL	T	CanV	Y	1560				L	(3;520#) PIPE
8	CL	T	CanV	Y	1040				L	(2;520#) PIPE
10	CL	T	CanV	Y	325				L	6" PIPE
11	CL	T	CanV	Y	175				L	SMALL PIPES
14	SL	T	Uni	Y	0	4'-8"	104	0"	R	DRIFT(Min)
17	WL	T	Uni	Y	-220		-220		L	Full Strip Uplift
18	WL	T	Uni	Y	-101	10'-0"	-101	0"	R	Addt Strip Uplift
19	SL	T	Uni	Y	0	2'-11"	64	0"	R	Corner Drift (Main)
	SL	T	Uni	Y	40		40		L	Side Drift
20	SL	T	Uni	Y	40		40		L	Uniform Drift Load
23	SL	T	Uni	Y	207		207		L	Condenser Drift
25	WL	T	Uni	Y	-76	14'-2"	-76	0"	R	Addt. Strip Lift (Skew)
26	SL	T	Uni	Y	104		104		L	Skew Drift

OTHER DRAWING NOTES:

- 1 SEE SHEET J1.0 FOR ERECTION NOTES.
- 2 TAG END OF ALL JOIST (U.N.O.) IS TOWARD THE BOTTOM OF THIS SHEET. NOTED OTHERWISE AT BAY A-B AND BAY D-E. TAG END OF JOIST TOWARD THE TOP OF THIS SHEET. JOIST MARK INDICATES TAGGED END
- 3 FLANGE WIDTHS:
INTERIOR FLANGE WIDTHS = 5 1/2" MIN. TO 8 1/2" MAX.
EXTERIOR FLANGE WIDTHS = 5" MIN. TO 6" MAX.
SKEWED FRAME FLANGE WIDTHS = 6"
- 4 ——— INDICATES SPRINKLER MAIN


City of Puyallup Development & Permitting Services ISSUED PERMIT			
Building	Planning	Engineering	Public Works
Fire	Traffic		

*Copy of
AS BUILT
DRAWING.*

RIDGE
LINE

130'-0"

AC-4.



B-21-0421

Search Information

Address: 1201 39th Ave SW, Puyallup, WA 98373
Coordinates: 47.1572713, -122.3083916
Elevation: 374 ft
Timestamp: 2021-03-05T06:47:17.540Z
Hazard Type: Seismic
Reference Document: ASCE7-16
Risk Category: II
Site Class: D-default



Basic Parameters

Name	Value	Description
S _S	1.268	MCE _R ground motion (period=0.2s)
S ₁	0.438	MCE _R ground motion (period=1.0s)
S _{MS}	1.522	Site-modified spectral acceleration value
S _{M1}	* null	Site-modified spectral acceleration value
S _{DS}	1.014	Numeric seismic design value at 0.2s SA
S _{D1}	* null <i>0.549</i>	Numeric seismic design value at 1.0s SA

0.438 (1.88)
= 0.823 (2/2)
= 0.549.

* See Section 11.4.8

Additional Information

Name	Value	Description
SDC	* null	Seismic design category
F _a	1.2	Site amplification factor at 0.2s
F _v	* null	Site amplification factor at 1.0s
CR _S	0.914	Coefficient of risk (0.2s)
CR ₁	0.898	Coefficient of risk (1.0s)
F _{GA}	0.5	MCE _G peak ground acceleration
F _{PGA}	1.2	Site amplification factor at PGA
PGA _M	0.6	Site modified peak ground acceleration

B-21-0421

T_L	6	Long-period transition period (s)
SsRT	1.268	Probabilistic risk-targeted ground motion (0.2s)
SsUH	1.388	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
SsD	1.5	Factored deterministic acceleration value (0.2s)
S1RT	0.438	Probabilistic risk-targeted ground motion (1.0s)
S1UH	0.487	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
S1D	0.6	Factored deterministic acceleration value (1.0s)
PGAd	0.5	Factored deterministic acceleration value (PGA)

* See Section 11.4.8

The results indicated here DO NOT reflect any state or local amendments to the values or any delineation lines made during the building code adoption process. Users should confirm any output obtained from this tool with the local Authority Having Jurisdiction before proceeding with design.

Disclaimer

Hazard loads are provided by the U.S. Geological Survey [Seismic Design Web Services](#).

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility for its accuracy. The material presented in the report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the report.

Search Information

Address: 1201 39th Ave SW, Puyallup, WA 98373
Coordinates: 47.1572713, -122.3083916
Elevation: 374 ft
Timestamp: 2021-03-05T06:47:03.821Z
Hazard Type: Wind



ASCE 7-16

MRI 10-Year 67 mph
 MRI 25-Year 73 mph
 MRI 50-Year 78 mph
 MRI 100-Year 82 mph
 Risk Category I 92 mph
 Risk Category II 97 mph
 Risk Category III 104 mph
 Risk Category IV 108 mph

ASCE 7-10

MRI 10-Year 72 mph
 MRI 25-Year 79 mph
 MRI 50-Year 85 mph
 MRI 100-Year 91 mph
 Risk Category I 100 mph
 Risk Category II 110 mph
 Risk Category III-IV 115 mph

ASCE 7-05

ASCE 7-05 Wind Speed 85 mph

The results indicated here DO NOT reflect any state or local amendments to the values or any delineation lines made during the building code adoption process. Users should confirm any output obtained from this tool with the local Authority Having Jurisdiction before proceeding with design.


Disclaimer

Hazard loads are interpolated from data provided in ASCE 7 and rounded up to the nearest whole integer. Per ASCE 7, islands and coastal areas outside the last contour should use the last wind speed contour of the coastal area – in some cases, this website will extrapolate past the last wind speed contour and therefore, provide a wind speed that is slightly higher. NOTE: For queries near wind-borne debris region boundaries, the resulting determination is sensitive to rounding which may affect whether or not it is considered to be within a wind-borne debris region.

Mountainous terrain, gorges, ocean promontories, and special wind regions shall be examined for unusual wind conditions.

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility for its accuracy. The material presented in the report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the

B-21-0421



ASCE 7-16
Seismic Loads per ASCE 7-16- Chapter 13 Seismic Design Requirements for Nonstructural Components


Project Name:
Location:

ASCE 7-16 Section 13.6 Seismic Demands on Nonstructural Components
All references below are to ASCE 7-16 (U.N.O.)

Input	
Mechanical and Electrical Component =	Air-side HVAC, fans, air handlers, air conditioning units, cabinet heaters, air distribution boxes
Table 13.6-1 Category =	Mechanical and Electrical Components
$S_s =$	1.268
$S_1 =$	0.438
Site Class (soil) =	D
Risk Category =	II Table 1.5-1
Average roof height of structure, h =	23.5 ft
Height in structure of point of attachment of component with respect to base, z =	23.5 ft
Component importance factor, $I_p =$	1.0 Sect 13.1.3
Operating weight of mechanical unit, $W_p =$	8181 lb.

Output	
Site Coefficient, $F_a =$	1 Table 11-4.1
$S_{MS} =$	1.268 Eqn 11.4-1
$S_{DS} =$	0.85 Eqn 11.4-3
$z/h =$	1
Component amplification factor, $a_p =$	2.5
Component response modification factor, $R_p =$	6
Component overstrength factor, $\Omega_o =$	2
$F_p =$	0.423 * W_p , Eqn 13.3-1
$F_{p_max} =$	1.353 * W_p , Eqn 13.3-2
$F_{p_min} =$	0.254 * W_p , Eqn 13.3-3
$F_{p_horiz} =$	0.423 * W_p
$F_{p_horiz} =$	3460.6 lb (ULT)
$F_{p_vert} = +/-$	0.169 * W_p , Sect. 13.3.1.2 (apply concurrently with horizontal force)
$F_{p_vert} = +/-$	1382.6 lb (ULT), Sect 13.3.1 (apply concurrently with horizontal force)

- NOTES:
1. Anchors in concrete shall be designed in accordance with Appendix D of ACI 318.
 2. Anchors in masonry shall be designed in accordance with TMS 402/ACI 530/ASCE 5. Anchors shall be designed to be governed by the tensile or shear strength of a ductile steel element. See Sect 13.4.2.2 for exception.
 3. Post-installed anchors in concrete shall be prequalified for seismic applications in accordance with ACI 355.2 or other approved qualification procedures. Post-installed anchors in masonry shall be prequalified for seismic applications in accordance with approved qualification procedures.
 4. Power actuated fasteners in concrete or steel shall not be used for sustained tension loads or for brace applications in Seismic Design Categories D, E, or F unless approved for seismic loading. Power actuated fasteners in masonry are not permitted unless approved for seismic loading. See Section 13.4.5 for exceptions.
 5. Friction clips in Seismic Design Categories D, E, or F shall not be used for supporting sustained loads in addition to resisting seismic forces.




Wind Loads per ASCE 7-16- Chapter 29 Other Structures and Building Appurtenances- Rooftop Equipment

Project Name:
 Location:

Program Limitations: 1. Mean roof height h less than or equal to 60 ft.

BUILDING, SITE, AND MECHANICAL UNIT INFORMATION

INPUT		
Building width, B =	458	ft (perpendicular to wind)
Building length, L =	328	ft (parallel to wind)
Building eave height, h_e =	26	ft
Building ridge height, h_r =	29	ft
Roof slope, s =	0.25 in./ft.	= 1.19 degrees
Risk Category =	II	
Wind velocity, V =	97	mi/hr = 75 mi/hr
Exposure =	B	
Topographic factor, K_{zt} =	1	
Wind directionality factor, K_d =	0.85	
M/U width =	12.92	ft (perpendicular to wind)
M/U depth =	8.33	ft (parallel to wind)
M/U height =	8.08	ft



OUTPUT			
Mean roof height, h =	26	ft	
Pressure exposure coeff, K_h =	0.7		$K_e = 1.00$
Velocity pressure, q_h =	14.33	psf	
$(GC_r)_{lateral}$ =	1.9		
Horizontal wind pressure, p_h =	27.2	psf (LRFD)	
Horizontal wind force, F_h =	2842.3	lb (LRFD)	
$(GC_r)_{uplift}$ =	1.5		
Vertical uplift wind pressure, p_v =	21.5	psf (LRFD)	
Vertical uplift wind force, F_v =	2313.4	lb (LRFD)	

NOTE: To convert to ASD multiply by 0.6


***** Property of Engineers Northwest, Inc., P.S.- Use by others unlawful *****

Lateral Loading on Mechanical Units

Input Cells = _____
 Project Number: _____
 Project Name: _____
 Location: _____
 Design By: _____

Input

Mechanical and Electrical Component = Air-side HVAC fans, air handlers, air conditioning units, cabinet heaters, air distribution boxes, and other mechanical
 Table 13.6-1 Category = Mechanical and Electrical Components
 Risk Category = II
 Building Width = 458 ft
 Roof height above ground level = 26 ft
 Mechanical unit operating weight = 8181 lb
 Mechanical unit length = 12.92 ft
 Mechanical unit depth = 8.33 ft
 Mechanical unit height = 8.08 ft
 Holddown clearance, C_{HD} = 3 in



Seismic Parameters


S_{DS} = 0.85
 Force inputted in = LRFD
 Horizontal seismic force, $F_{p,horiz}$ = 3460.6 lb
 Vertical seismic force, $F_{p,vert}$ = 1382.6 lb
 Vertical center of mass of mech. unit, h = 4.04 ft
 See seismic loads spreadsheet for additional data

Wind Parameters

Force inputted in = LRFD
 Horizontal wind force, F_h = 2843 lb
 Vertical uplift wind force, F_v = 2314 lb
 See wind loads spreadsheet for additional data

Output

LATERAL LOADS AND REACTIONS	Ultimate (LRFD)	Working (ASD)
Seismic overturning moment =	13981 ft-lb	9787 ft-lb
Seismic uplift @ each end of unit =	0 lb	0 lb
Seismic shear @ each side of unit =	1730 lb	1211 lb
Wind overturning moment =	11486 ft-lb	5891 ft-lb
Wind uplift @ each end of unit =	0 lb	0 lb
Wind shear @ each side of unit =	1422 lb	853 lb



RTU CONNECTION CHECK: INPUT

RTU CURB DIMS: 146 IN LENGTH 93 IN WIDTH

SHEAR CHECK: (ASD)

SHEAR DEMAND: 1211 LBS (SEE LATERAL LOADING FOR MECHANICAL UNITS SPREADSHEET)

USE 11/32" DIA SCREWS @ 6" O.C

CONNECTING MEMBER GAGE: 14 GAGE

SHEAR CAPACITY: 651 LBS CAPACITY OF SINGLE 1/4" DIA SCREWS PER SCREW SCHEDULE

NUMBER OF SCREWS REQ'D: 1211 / 651 = 2 SCREWS

CONNECTION LENGTH REQ'D:
6" + 6" (both sides) + 6 * 1 (screw spacing) = 18 IN

RTU SHORT SIDE LENGTH:	93 IN	>	18 IN	OK
------------------------	-------	---	-------	----

UPLIFT CHECK: (ASD)

UPLIFT DEMAND: 0 LBS

USE 1/2" DIA A307 BOLT (TWO BOLTS EACH CORNERS, 8 BOLTS TOTAL)

BOLT CAPACITY: 22.5 KSI * 0.196 IN^2 = 4.41 K

TOTAL 4 BOLTS @ EACH SIDE TO TAKE THE UPLIFT FORCES:

TOTAL BOLT CAPACITY: 4 * 4.41 = 17.64 K

0 LBS	<	17.64 K	OK
-------	---	---------	----


RN UNITS 26-70 TON



WITH ECONOMIZER


CLEARANCES	
LOCATION	UNIT SIZE 26-70 TON
RETURN AIR BACK	48
VENT SIDE FRONT	48
LEFT SIDE	48
RIGHT SIDE	70
TOP	UNOBSTRUCTED

NOTE: RIGHT AND LEFT SIDE UNIT CLEARANCES ARE INTERCHANGEABLE ON UNITS THAT DO NOT HAVE THE HYDRONIC HEATING OPTION. (UNITS WITH HYDRONIC HEAT MUST HAVE 70" RIGHT SIDE ACCESS FOR SERVICE.)






DETAIL A

NOTE: 26-40 TON UNITS INCLUDES A SINGLE COOLING COIL. 50-70 TON UNIT INCLUDE TWO COOLING COILS.




DETAIL B





B-21-0421

KNOCKDOWN CURB, STANDARD


KIT# K00779




CURB WEIGHTS
14IN CURB=192LBS (234LBS WITH DUCT SUPPORT RAIL)
24IN CURB=291LBS (333LBS WITH DUCT SUPPORT RAIL)



CURB WITHOUT DUCT SUPPORT RAIL KIT



STRUCTURAL CALCULATIONS



PROJECT # 99090013 PROJECT C. PUYALLUP, WA.

DATE 12/21/2021

SUBJECT HANGING UNIT CHECK.

SHEET _____ OF _____
BY _____

• To CHECK THE NEW HANGING UNITS.

AH-1 150#

AH-2 150#

AH-5 150#

AH-6 150#.

GRAVITY CHECK: $\frac{3}{8}" \text{ } \phi \text{ ROD} : 730\# > \frac{150\#}{4} = 38\#.$

$5' \text{ PL1000} : 680\# \times 0.5 \times 0.85 \times 0.82 = 237\#$

JOIST : SEE ATTACHED STEEL JOIST CHECK $> 75\#.$

LATERAL CHECK: $1030\# > 47\#.$ OK

**** Property of Engineers Northwest, Inc., P.S.- Use by others unlawful ****


EXISTING STEEL JOIST ANALYSIS WITH NON-UNIFORM LOADS

Input =
 Project Number =
 Project Name = HVAC Replacement
 Location =
 Design By =

INPUT

JOIST INFO:

Joist Type = K-Series
 Joist Designation = 24KS
 Span, L = 43 ft
 Modulus of Elasticity, E = 29000 ksi
 Moment of Inertia, I_x = 843 in⁴



ORIGINAL DESIGN LOADS

Full Uniform:

w = lb/ft

Point:

	a (ft)	P (lb)
1	15	0
2		
3		
4		
5		
6		
7		
8		

	Start		End	
	b (ft)	w ₁ (lb/ft)	c (ft)	w ₂ (lb/ft)
1				
2				
3				
4				
5				

Moment:

	d (ft)	M (ft-lb.)
1		
2		
3		

NEW DESIGN LOADS

Full Uniform:

w = lb/ft


Point:

	a (ft)	P (lb)
1	15	75
2		
3		
4		
5		
6		
7		
8		

	Start		End	
	b (ft)	w ₁ (lb/ft)	c (ft)	w ₂ (lb/ft)
1				
2				
3				
4				
5				

Moment:

	d (ft)	M (ft-lb.)
1		
2		
3		



OUTPUT

ORIGINAL DESIGN LOADS

End Reactions:

$$R_L = 4128 \text{ lbs.}$$

$$R_R = 4128 \text{ lbs.}$$

Minimum Design Web Shear:

$$V_{W_MIN} = 1032.01 \text{ lbs. (25\% of end reaction per SJI Specifications)}$$

Maximum Moments:

$$M_{MAX}^{(+)} = 44376 \text{ ft-lb @ } x = 21.5 \text{ ft}$$

$$M_{MAX}^{(-)} = -4.13E-06 \text{ ft-lb @ } x = 43 \text{ ft}$$

Point of Zero Shear:

$$x_{(v=0)} = 21.5 \text{ ft}$$

Maximum Deflections:

$$-\Delta_{MAX} = -0.69 \text{ in @ } x = 21.5 \text{ ft}$$

$$+\Delta_{MAX} = 0 \text{ in @ } x = 43 \text{ ft}$$

$$\Delta_{RATIO} = L/748$$

NEW DESIGN LOADS

End Reactions:

$$R_L = 3811.3372 \text{ lbs.}$$

$$R_R = 3788.66 \text{ lbs.}$$

Maximum Moments:

$$M_{MAX}^{(+)} = 41011.331 \text{ ft-lb @ } x = 21.3505 \text{ ft}$$

$$M_{MAX}^{(-)} = -3.79E-06 \text{ ft-lb @ } x = 43 \text{ ft}$$

Point of Zero Shear:

$$x_{(v=0)} = 21.35 \text{ ft}$$

Note: If the location of the point of zero shear moves more than 1'-0" +/- between the original design loads and the new design loads, stress reversals could occur in the diagonal web members. If adjacent diagonal web members are not the same size, further detailed joist analysis would be required.

Maximum Deflections:

$$-\Delta_{MAX} = -0.64 \text{ in @ } x = 21.4748 \text{ ft}$$

$$+\Delta_{MAX} = 0 \text{ in @ } x = 43 \text{ ft}$$

$$\Delta_{RATIO} = L/806$$

MAXIMUM STRESS RATIOS


$$U_{shear} = 0.948 \text{ @ } x = 14.62 \text{ ft}$$

$$U_{bending} = 0.929 \text{ @ } x = 13.76 \text{ ft}$$


ok.

COMMENTS:


Shear Diagram



Moment Diagram



--- = curves for original design loads — = curves for new design loads



ASCE 7-16
Seismic Loads per ASCE 7-16- Chapter 13 Seismic Design Requirements for Nonstructural Components

Project Name:
Location:

ASCE 7-16 Section 13.6 Seismic Demands on Nonstructural Components
All references below are to ASCE 7-16 (U.N.O.)

Input	
Mechanical and Electrical Component =	Air-side HVAC, fans, air handlers, air conditioning units, cabinet heaters, air distribution boxes
Table 13.6-1 Category =	Mechanical and Electrical Components
S_s =	1.268
S_1 =	0.438
Site Class (soil) =	D
Risk Category =	II Table 1.5-1
Average roof height of structure, h =	23.5 ft
Height in structure of point of attachment of component with respect to base, z =	14 ft
Component importance factor, I_p =	1.0 Sect 13.1.3
Operating weight of mechanical unit, W_p =	150 lb.

Output	
Site Coefficient, F_a =	1 Table 11.4.1
S_{MS} =	1.268 Eqn 11.4-1
S_{DS} =	0.85 Eqn 11.4-3
z/h =	0.596
Component amplification factor, a_p =	2.5
Component response modification factor, R_p =	6
Component overstrength factor, Ω_o =	2
F_p =	0.309 * W_p , Eqn 13.3-1
F_{p_max} =	1.353 * W_p , Eqn 13.3-2
F_{p_min} =	0.254 * W_p , Eqn 13.3-3
F_{p_horiz} =	0.309 * W_p
F_{p_horiz} =	46.4 lb (ULT)
$F_{p_vert} = +/-$	0.169 * W_p , Sect. 13.3.1.2 (apply concurrently with horizontal force)
$F_{p_vert} = +/-$	25.4 lb (ULT), Sect 13.3.1 (apply concurrently with horizontal force)

- NOTES:
1. Anchors in concrete shall be designed in accordance with Appendix D of ACI 318.
 2. Anchors in masonry shall be designed in accordance with TMS 402/ACI 530/ASCE 5. Anchors shall be designed to be governed by the tensile or shear strength of a ductile steel element. See Sect 13.4.2.2 for exception.
 3. Post-installed anchors in concrete shall be prequalified for seismic applications in accordance with ACI 355.2 or other approved qualification procedures. Post-installed anchors in masonry shall be prequalified for seismic applications in accordance with approved qualification procedures.
 4. Power actuated fasteners in concrete or steel shall not be used for sustained tension loads or for brace applications in Seismic Design Categories D, E, or F unless approved for seismic loading. Power actuated fasteners in masonry are not permitted unless approved for seismic loading. See Section 13.4.5 for exceptions.
 5. Friction clips in Seismic Design Categories D, E, or F shall not be used for supporting sustained loads in addition to resisting seismic forces.

Threaded Access

B3205 - Threaded Rod (right-hand threads - both ends)

B3205L - Threaded Rod (right & left hand threads)

Size Range: 3/8"-16 thru 3"-4 rod


Material: Steel

Function: Recommended for use as a hanger support in hanger assemblies. Rod is threaded on both ends with right hand threads of the length shown. Also available with left and right hand threads - specify Fig. B3205L when ordering.

Maximum Temperature: 750°F (399°C)

Finish: Plain. Contact customer service for alternative finishes and materials.

Order By: Part number, rod size, length and finish



Part No.	Thread Size A	Standard		Design Load			
		Thread Length	TL	650°F (343°C)		750°F (399°C)	
		in.	(mm)	Lbs.	(kN)	Lbs.	(kN)
B3205-3/8 x 'L'	3/8"-16	2 1/2"	(63.5)	730	(3.25)	572	(2.54)
B3205-1/2 x 'L'	1/2"-13	2 1/2"	(63.5)	1350	(6.00)	1057	(4.70)
B3205-5/8 x 'L'	5/8"-11	2 1/2"	(63.5)	2160	(9.61)	1692	(7.52)
B3205-3/4 x 'L'	3/4"-10	3"	(76.2)	3230	(14.37)	2530	(11.25)
B3205-7/8 x 'L'	7/8"-9	3 1/2"	(88.9)	4480	(19.93)	3508	(15.60)
B3205-1 x 'L'	1"-8	4"	(101.6)	5900	(26.24)	4620	(20.55)
B3205-1 1/8 x 'L'	1 1/8"-7	4 1/2"	(114.3)	7450	(33.14)	5830	(25.93)
B3205-1 1/4 x 'L'	1 1/4"-7	5"	(127.0)	9500	(42.25)	7440	(33.09)
B3205-1 1/2 x 'L'	1 1/2"-6	6"	(152.4)	13800	(61.38)	10807	(48.07)
B3205-1 3/4 x 'L'	1 3/4"-5	7"	(177.8)	18600	(82.73)	14566	(64.79)
B3205-2 x 'L'	2"-4 1/2	8"	(203.2)	24600	(109.42)	19625	(87.29)
B3205-2 1/4 x 'L'	2 1/4"-4 1/2	9"	(228.6)	32300	(143.67)	25295	(112.51)
B3205-2 1/2 x 'L'	2 1/2"-4	10"	(254.0)	39800	(177.03)	31169	(138.64)
B3205-2 3/4 x 'L'	2 3/4"-4	11"	(279.4)	49400	(219.73)	38687	(172.08)
B3205-3 x 'L'	3"-4	12"	(304.8)	60100	(267.32)	47066	(209.35)

ATR - All Threaded Rod 120" (3.05m) Lengths

Fig. 99 - All Threaded Rod Cut To Length


Size Range: 3/8"-16 thru 1 1/2"-6 rod in 120" (3.05m) lengths or cut to length

Material: Steel

Maximum Temperature: 750°F (399°C)

Finish: Plain. Contact customer service for alternative finishes and materials.

Order By: Part number, rod diameter and finish



Part No. - Size x Length ATR	Size x Length Fig.99	Threads Per Inch	Recommended Load		Approx. Wt./100 Ft.	
			Lbs.	(kN)	Lbs.	(kg)
ATR 1/4" x 120	99-1/4" x length	20	240	(1.07)	12	(5.44)
ATR 3/8" x 120	99-3/8" x length	16	730	(3.24)	29	(13.15)
ATR 1/2" x 120	99-1/2" x length	13	1350	(6.00)	53	(24.04)
ATR 5/8" x 120	99-5/8" x length	11	2160	(9.60)	89	(40.37)
ATR 3/4" x 120	99-3/4" x length	10	3230	(14.37)	123	(55.79)
ATR 7/8" x 120	99-7/8" x length	9	4480	(19.93)	170	(77.11)
ATR 1" x 120	99-1" x length	8	5900	(26.24)	225	(102.06)
ATR 1 1/8" x 120	99-1 1/8" x length	7	7450	(33.14)	280	(127.01)
ATR 1 1/4" x 120	99-1 1/4" x length	7	9500	(42.25)	351	(159.21)
ATR 1 1/2" x 120	99-1 1/2" x length	6	13800	(61.38)	510	(231.33)

All dimensions in charts and on drawings are in inches. Dimensions shown in parentheses are in millimeters unless otherwise specified.

Threaded Accessories

P1000 & P1001 Channels

UNIST

1 1/2" Channel

P1000 - BEAM LOADING

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	1,690	0.06	1,690	1,690	1,690
36	1,130	0.13	1,130	1,130	900
48	850	0.22	850	760	500
60	680	0.35	650	480	320
72	560	0.50	450	340	220
84	480	0.68	330	250	160
96	420	0.89	250	190	130
108	360	1.14	200	150	100
120	340	1.40	160	120	80
144	260	2.00	110	80	60
168	240	2.72	80	60	40
192	210	3.55	60	50	NR
216	190	4.58	50	40	NR
240	170	5.62	40	NR	NR

P1001 - BEAM LOADING

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	3,500*	0.02	3,500*	3,500*	3,500*
36	3,190	0.07	3,190	3,190	3,190
48	2,390	0.13	2,390	2,390	2,390
60	1,910	0.20	1,910	1,910	1,620
72	1,600	0.28	1,600	1,600	1,130
84	1,370	0.39	1,370	1,240	830
96	1,200	0.51	1,200	950	630
108	1,060	0.64	1,000	750	500
120	960	0.79	810	610	410
144	800	1.14	560	420	280
168	680	1.53	410	310	210
192	600	2.02	320	240	160
216	530	2.54	250	190	130
240	480	3.16	200	150	100

P1000 - COLUMN LOADING

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	3,550	10,740	9,890	8,770	7,740
36	3,190	8,910	7,740	6,390	5,310
48	2,770	7,260	6,010	4,690	3,800
60	2,380	5,910	4,690	3,630	2,960
72	2,080	4,840	3,890	2,960	2,400
84	1,860	4,040	3,200	2,480	1,980
96	1,670	3,480	2,750	2,110	1,660
108	1,510	3,050	2,400	1,810	**
120	1,380	2,700	2,110	**	**
144	1,150	2,180	1,660	**	**

P1001 - COLUMN LOADING

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	6,430	24,280	23,610	22,700	21,820
36	6,290	22,810	21,820	20,650	19,670
48	6,160	21,410	20,300	18,670	16,160
60	6,000	20,210	18,670	15,520	12,390
72	5,620	18,970	16,160	12,390	8,950
84	5,170	16,950	13,630	9,470	6,580
96	4,690	14,890	11,190	7,250	5,040
108	4,170	12,850	8,950	5,730	3,980
120	3,690	10,900	7,250	4,640	**
144	2,930	7,630	5,040	**	**

P1000/P1001 - ELEMENTS OF SECTION

Parameter	P1000	P1001
Area of Section	0.555 in ²	1.111 in ²
Axis 1-1		
Moment of Inertia (I)	0.185 in ⁴	0.928 in ⁴
Section Modulus (S)	0.202 in ³	0.571 in ³
Radius of Gyration (r)	0.577 in	0.914 in
Axis 2-2		
Moment of Inertia (I)	0.236 in ⁴	0.471 in ⁴
Section Modulus (S)	0.290 in ³	0.580 in ³
Radius of Gyration (r)	0.651 in	0.651 in

Notes:

* Load limited by spot weld shear.

** KL/r > 200

NR = Not Recommended.

- Beam loads are given in *total* uniform load (W Lbs) not uniform load (w lbs/ft or w lbs/in).
- Beam loads are based on a simple span and assumed to be adequately laterally braced. Unbraced spans can reduce beam load carrying capacity. Refer to Page 62 for reduction factors for unbraced lengths.
- For pierced channel, multiply beam loads by the following factor:

"KO" Series.....95%	"T" Series85%
"HS" Series90%	"SL" Series85%
"H3" Series.....90%	"DS" Series.....70%
"WT" Series.....85%	
- Deduct channel weight from the beam loads.
- For concentrated midspan point loads, multiply beam loads by 50% and the corresponding deflection by 80%. For other load conditions refer to page 18.
- All beam loads are for bending about Axis 1-1.

B-21-0421

P1000 BRACE DESIGN LOAD

Unsupported Length	Compression Load*	
	lbs	(kN)
<i>in (mm)</i>		
24 (610)	4,200	18.50
36 (914)	3,650	16.00
48 (1219)	3,130	13.50
60 (1524)	2,650	11.50
72 (1829)	2,230	9.50
84 (2134)	1,850	8.00
96 (2438)	1,570	6.50
108 (2743)	1,360	6.00
120 (3048)	1,200	5.00




*Note: 1. Maximum axial load under seismic loading conditions.
2. The design load shall not exceed the allowable loads for connection detail.

SPF 400 DESIGN LOAD

* A Trademark of Lord & Sons, Inc.

Wire Rope Diameter in (mm)	4 Way Splayed				Single Cable	
	Transverse Load		Longitudinal Load		Transverse Load	
	lbs	(kN)	lbs	(kN)	(lbs)	(kN)
3/16 (5)	1050	4.67	1116	4.96	650	2.89

Note: 1. Allowable loads have been determined by the manufacturer's testing, analysis, and technical specifications.
2. Galvanized Wire Rope, 7 x 19 IWSC, RHRL (PRESTRETCHED)
3. Maximum torque on nut: 50 ft-lbs.
4. Safety Factor of 3 for prestretched cable.

<p align="center">A P P R O V E D Fixed Equipment Anchorage Office of Statewide Health Planning and Development</p> <p align="center">OPA-0120 Apr 25, 2003</p> <p align="center">**** Valid for 3 Years Maximum ****</p>  <p align="center"><i>Bill Stachlin</i></p> <p align="center">Bill Stachlin (916) 324-9106</p>	<p align="right">UNISTRUT®</p> <p align="right">35660 Clinton Street Wayne, Michigan 48184 PH: (800) 521-7730 FAX: (734) 721-4106</p>  <p>JOSEPH L. LA BRIE Structural Engineer No. SE 3566 55 E. Walnut St. Suite 277 Arcadia, CA 91006</p>  <table border="1"> <tr> <td>DATE:</td> <td>04/25/2003</td> <td>PAGE:</td> <td>4-6</td> </tr> </table>	DATE:	04/25/2003	PAGE:	4-6
DATE:	04/25/2003	PAGE:	4-6		