



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Comment Notice

Permit Application # PRROW20220314

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Engineering Review (Reviewed By: Linda Lian, (253)841-5577, LindaL@PuyallupWA.gov)

- ◆ Please submit a TCP that shows more than flaggers. Using the following link you may find a TCP that will work for this location: <https://www.cityofpuyallup.org/885/Traffic-Control> Please note that day time lane closure at anyone time cannot exceed three minutes, otherwise the work must be done at night. TCP Sheet 1
- ◆ Please explain how the new pump will be taken from one side of the street to the other side. And how long will it take? TCP Sheet 1
- ◆ Please provide a letter of acknowledgment from Multi-care Hospital. TCP Sheet 1
- ◆ In order to leave the forklift in this area without continuous use of flaggers 11' wide travel lanes in both direction must be maintained at all time. Verify if this can be maintained by showing lane width on the TCP TCP Sheet 1
- ◆ Please provide width information for the area shaded in red. In order to leave the forklift in this area without continuous use of flaggers 11' wide travel lanes in both direction must be maintained at all time. Verify if this can be maintained. TCP Sheet 2

To resubmit, you must address all comments and complete the [resubmittal form](#). When you are ready to resubmit, you can do so by using the customer portal and uploading a “new version” of the submittal requirement. In addition, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid. Please note, partial resubmittals will be deemed incomplete and returned.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov