



City of Puyallup
Building Division
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Comment Notice

Permit Application # PRCTI20210027

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Planning Review (Reviewed By: Josh Kubitza, (253)383-2422, jkubitza@ahbl.com)

- ♦ Per PMC 20.59A.030, an eligible support structure includes any structure, other than a tower, that supports or houses wireless communication equipment that has been reviewed and approved under the applicable zoning or siting process. The proposal includes completely new pad with new wireless equipment (Base station) that has not been review and approved under than applicable zoning or siting process. As such, It would appear that the project is not a modification of eligible support structure subject to review under Section 6409 of the Spectrum Act. Staff will review the project against PMC 20.59 through this building permit. If you would like the project to be reviewed under PMC 20.59A.030 Eligible Facilities Modification Code, the City will need a detailed narrative that describes how the project is an modification of eligible support structure.
- ♦ PMC 20.59.040.5.c requires that equipment facilities used to house wireless communications equipment shall be located within buildings or placed underground when possible. When they cannot be located in buildings or placed underground, equipment shelters, or cabinets shall be screened. Please provide a detailed narrative addressing these standards and update site plans as needed to demonstrate compliance.
- ♦ PMC 20.59.040.5.d requires that related wireless communication equipment facilities shall be of neutral colors. The application materials do not denote the color of the equipment. Please revise drawings to denote the equipment colors or add a note to the site plans that the wireless communication equipment shall be neutral colors.

To resubmit, you must address all comments and complete the [resubmittal form](#). Please note, partial resubmittals will be deemed incomplete and returned. When you are ready to resubmit, you can do so using the customer portal, by uploading a “new version” of the submittal requirement. In addition, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid. Please note, partial resubmittals will be deemed incomplete and returned.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov