



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 11, 2022 **Inspection Result:** **PASSED W/
CONDITIONS**

Permit Number: B-21-0820

Property Address: 1019 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: GATEWAY CONSTRUCTION SRVCS INC 5506 6TH AVE STE 210 S
SEATTLE, WA 98108

To construct: TI ~ MINIMAL DESIGN CHANGES; NO MECH/PLUMB CHANGES ~ STE
210/BUILDERS CAPITAL
REVISION INCLUDES MECH AND PLUMB

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: INSP PLUMBING ROUGH IN - SPOKE WITH CONTRACTOR & PLUMBER REGARDING DELETING SUPPLY @ COUNTER IN BREAKROOM OR PROVIDING A RPBA

Corrections:

Sincerely,

Gary Webster

Building Inspector

GWebster@PuyallupWA.gov

(253) 841-5590