



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 14, 2022

Inspection Result: **FAILED**

Permit Number: E-20-0612

Property Address: 3213 WILDWOOD PARK DR, PUYALLUP, WA 98374;

Contractor: PEASE & SONS PO BOX 44100 TACOMA, WA 98444

To construct: CIVILS ~ FERRUCCI JHS REMODEL & ADDITION

2021 STORM SDC FEES UPDATED

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The south existing pond has silt running through it and into the offsite storm system. The pipe heads east approximately 50LF through a flow control structure then another 130LF east through another structure then 187LF south through an easement to another structure located in the cul-de-sac on 36th Pl. SE. The CB to the right of the buss entrance has silt running into it. This CB is an off site CB and runs to a perforated pipe under the sidewalk. I notified the contractor who notified the sub contractor. The only thing that was performed to aid in the run off was moving some spalls and maybe adding straw. The silt is still running into both off site systems.

Corrections:

- 1 1. Temporarily raise the CB in the existing south pond to gain proper free bored and add silt fence and rock around the CB.
2. Install check dams for silt runoff to the existing south pond.
3. Locate the existing flow control structure to insure proper functioning and maintenance.
4. Divert the silty run off from going to the ROW CB and clean the CB sock.
5. ALL pipes leading to both off site systems will need to be jetted and TV'ed for cleanliness.
6. The city needs this done ASAP.

If this is not completed in a timely manner, the city will be forced to post a stop work order on all site permits and inspections.

The site's CESCL needs to monitor discharge and report NTU's above 25.

NO track out, keep the on site and off site pavements cleaned.



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

Jason Little
Engineering Tech IV
JLittle@PuyallupWA.gov
(253) 435-3636