



City of Puyallup
Engineering Division
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Comment Notice

Permit Application # PRFUP20220125

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Engineering Review (Reviewed By: Linda Lian, (253)841-5577, LindaL@PuyallupWA.gov)

- ◆ It is the city's opinion that a further effort on your part is required to place your utility under the sidewalk. This may require that you remove sidewalk panels and/or pothole them. This can be accomplished only by obtaining a permit first. Sheet Number: 1 of 18
- ◆ Vault will not be placed in a lane of travel. Sheet 9 of 18
- ◆ Can vault be placed at back of sidewalk? Is there a utility easement that Zayo Group can participate in? Sheet 12 of 18
- ◆ Relocate vault, shift it near the northerly edge of ROW. Sheet 16 of 18

To resubmit, you must address all comments and complete the [resubmittal form](#).

When you are ready to resubmit, you can do so by using the customer portal and uploading a "new version" of the submittal requirement.

Please note, partial resubmittals will be deemed incomplete and returned.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov