



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 16, 2022 **Inspection Result:** **PARTIAL PASS**

Permit Number: B-21-0544

Property Address: 4423 S MERIDIAN;

Contractor: PROBUILD CONSTRUCTION 12112 92ND AVE CT E PUYALLUP, WA
98373

To construct: TI ~ TANDOORI GRILL

BLDG/PLUMB/MECH

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide complete set of city approved plans on-site at time of inspection. (inspection of below slab plumbing only)
- 2 ; provide as built plumbing plan approval from engineer of record.
- 1 ; remove abandoned plumbing and cap below slab prior to below slab inspection.
- 4 ; provide test on D.W.V. with 10' head test at time of inspection.

Sincerely,

Gary Webster

Building Inspector

GWebster@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 841-5590