



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Comment Notice

Permit Application # PRSG20220116

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Building Review (Reviewed By: David Leahy, (253)435-3618, DLeahy@PuyallupWA.gov)

- ♦ Plans need to be stamped by someone that has a WA. ST. seal. Page LN-P6
- ♦ Plan size needs to be a minimum of 11" X 17"
- ♦ Need to use the 2018 IBC and current ASCE 7-16 standard for all calcs and references. Pages in calc. package.
- ♦ Plans need to be stamped by someone that has a WA. ST. seal.

Planning Review (Reviewed By: Nabila Comstock, (253)770-3361, NComstock@PuyallupWA.gov)

- ♦ (a) The square footage of a sign made up of letters, words, symbols, trademarks and business or corporate colors within a frame shall be determined from the outside edge of the frame itself. The square footage of the proposed monument sign is 11' -10 1/2 " x 3' 7" which equals 42.6 SF. Please adjust application to show the accurate SF [submittal documents, pg. 1]
- ♦ (a) The height of a monument sign shall be measured from the finished grade immediately abutting the base of the sign; in no event shall a monument sign be installed on an earthen berm, retaining wall or otherwise artificially created/graded surface as to elevate it above the surrounding landscape in an effort to exceed the maximum height for monument signs set forth herein.

To resubmit, you must address all comments and complete the [resubmittal form](#). When you are ready to resubmit, you can do so using the customer portal, by uploading a "new version" of the submittal requirement. In addition, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.

Please note, partial resubmittals will be deemed incomplete and returned.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov