



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 18, 2022                      **Inspection Result:**     **PASSED**

**Permit Number:** B-20-0984

**Property Address:** 3500 S MERIDIAN                      ;

**Contractor:** ROD BANE MANAGEMENT DBA RBM 6668 E OLIVE AVE FRESNO, CA  
93727

**To construct:** TI - EXISTING SEARS/ BUILDING INTO BOWLING & ARCADE VENUE ~  
ROUND 1

BLDG/PLUMB/MECH

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** INSP ENERGY INSPECTION - cavity under bowling lanes filled with batt insulation

**Corrections:**

Sincerely,

Gary Webster

Building Inspector

GWebster@PuyallupWA.gov

(253) 841-5590