



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 21, 2022                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** B-20-0984

**Property Address:** 3500 S MERIDIAN                      ;

**Contractor:** ROD BANE MANAGEMENT DBA RBM 6668 E OLIVE AVE FRESNO, CA  
93727

**To construct:** TI - EXISTING SEARS/ BUILDING INTO BOWLING & ARCADE VENUE ~  
ROUND 1

BLDG/PLUMB/MECH

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** light test for grease duct - all sections tested on ground are ok, will do 2nd light test of seams when assembled

**Corrections:**

Sincerely,

Gary Webster

Building Inspector

GWebster@PuyallupWA.gov

(253) 841-5590