



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 22, 2022                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCTI20220005

**Property Address:** 1019 39TH AVE SE, PUYALLUP, WA 98374; 1015 39TH AVE SE,  
PUYALLUP, WA 98374;

**Contractor:** GATEWAY CONSTRUCTION SRVCS INC 5506 6TH AVE STE 210 S  
SEATTLE, WA 98108

**To construct:** This mainly consists of new finishes, new light fixtures, new tv locations, and some new millwork. There will be (1) interior partition constructed in the 1015 building at the west lobby, first floor. No existing partitions will be demolished, the only demo will be existing finishes to be replaced with new finishes. No additions or subtractions to the overall SF of each lobby/common area will happen. No mechanical or plumbing changes will happen.

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** new partition wall next to elevator - ok  
spoke about sealing new dead space up to avoid having to add fire protection.

**Corrections:**

Sincerely,

Gary Webster  
Building Inspector



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

GWebster@PuyallupWA.gov

(253) 841-5590