

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Mar 28, 2022	Inspection Result:	FAILED
Permit Number: Property Address:	B-21-0820 1019 39TH AVE SE, PUYALLUP, WA 98374;		
Contractor:	GATEWAY CONSTRUCTION SRVCS INC 5506 6TH AVE STE 210 S		
-	SEATTLE, WA 98108		
To construct:	TI ~ MINIMAL DESIGN CHANGES; NO MECH/PLUMB CHANGES ~ ST		
	210/BUILDERS CAPIT	AL	
	REVISION INCLUDES	MECH AND PLUMB	

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1 provide rpba @ water supply at counter in breakroom or delete

Sincerely,

Gary Webster Building Inspector GWebster@PuyallupWA.gov (253) 841-5590