


All structural details for the installation of this roll-up gate must be incorporated into the plans and stamped by the Engineer of record not just as a part of this calculation documents.



Project:

UPS ROLL UP GATE


Location

4227 S MERIDIAN STE, PUYALLUP, WA 98373

PERMIT SUBMITTAL



PRCTI20220017



5816 SW Gillcrest ct
Portland, OR 97221
Ph: 503.896.7712

SKETCH



Project:

Location:

Client:


Date:

By:

City of Puyallup Development & Permitting Services	
ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic

Sheet #

Job #




GATE TOP RESTRAINT SUPPORT

INSTALL 24" OC



5816 SW Gillcrest ct
Portland, OR 97221
Ph: 503.896.7712



CALCULATIONS



Project:

Location:

Client:

Date:

By:

City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic

Sheet #

Job #

PROJECT INFORMATION

UPS GATE SUPPORT

ADDRESS: 4227 S MERIDIAN STE
PUYALLUP, WA 98373

SEISMIC: $S_d_s = 1.008$ $I = 1.0$

CODE IBC 2018



Search Information

Address: 4227 S Meridian, Puyallup, WA 98373, USA

Coordinates: 47.1515005, -122.2923182

Elevation: 442 ft


Timestamp: 2022-01-14T22:22:29.330Z

Hazard Type: Seismic

Reference Document: ASCE7-16

Risk Category: II

Site Class: D-default



Basic Parameters


Name	Value	Description
S_S	1.26	MCE_R ground motion (period=0.2s)
S_1	0.435	MCE_R ground motion (period=1.0s)
S_{MS}	1.512	Site-modified spectral acceleration value
S_{M1}	* null	Site-modified spectral acceleration value
S_{DS}	1.008	Numeric seismic design value at 0.2s SA
S_{D1}	* null	Numeric seismic design value at 1.0s SA

* See Section 11.4.8

▼Additional Information

Name	Value	Description
SDC	* null	Seismic design category
F_a	1.2	Site amplification factor at 0.2s
F_v	* null	Site amplification factor at 1.0s
CR_S	0.914	Coefficient of risk (0.2s)
CR_1	0.898	Coefficient of risk (1.0s)
PGA	0.5	MCE_G peak ground acceleration
F_{PGA}	1.2	Site amplification factor at PGA
PGA_M	0.6	Site modified peak ground acceleration

T_L	6	Long-period transition period (s)
SsRT	1.26	Probabilistic risk-targeted ground motion (0.2s)
SsUH	1.379	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
SsD	1.5	Factored deterministic acceleration value (0.2s)
S1RT	0.435	Probabilistic risk-targeted ground motion (1.0s)
S1UH	0.484	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
S1D	0.6	Factored deterministic acceleration value (1.0s)
PGAd	0.5	Factored deterministic acceleration value (PGA)



* See Section 11.4.8

The results indicated here DO NOT reflect any state or local amendments to the values or any delineation lines made during the building code adoption process. Users should confirm any output obtained from this tool with the local Authority Having Jurisdiction before proceeding with design.

Disclaimer

Hazard loads are provided by the U.S. Geological Survey [Seismic Design Web Services](#).

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in the report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the report.



5816 SW GILCREST CT.
PORTLAND, OR 97221
TEL: 503.896.7712

Project:

Location:

Client:

Date:

By:

City of Puyallup
Development & Permitting Services

ISSUED PERMIT

Building

Planning

Engineering

Public Works

Fire

Traffic

Sheet #

Job #

GATE INFO

TYPICAL DOOR WT $\approx 184^{\#}$ (USE $200^{\#}$)

LATERAL RESTRAINT @ TOP

AL GATE DOOR $q_p = 2\frac{1}{2}$, $R_p \sim 3\frac{1}{2}$

$$F_p = \frac{0.4(1)(2.5)(1.008)wt(1+2\frac{2}{3})}{3\frac{1}{2}} \approx 0.29wt$$

$$wt \sim 200^{\#} \therefore F_p \approx 60^{\#}$$

$$F_v = 0.2(1.008)(1)(200^{\#}) \approx 40^{\#}$$


$$\therefore R = [(60)^2 + (40)^2]^{\frac{1}{2}} \\ \approx 72^{\#}$$

C 45° BRACE WIRE

$$60^{\#} / \cos 45^{\circ} \approx 85^{\#}$$

MAX THRUST TO
POD / STRUT

$$F_v = 40^{\#}$$





5816 SW GILCREST CT.
PORTLAND, OR 97221
TEL: 503.896.7712

Project:

Location:

Client:

Date:

By:

City of Puyallup
Development & Permitting Services

ISSUED PERMIT

Building

Planning

Engineering

Public Works

Fire

Traffic

Sheet #

Job #

GATE RESTRAINT (CONT)

THRUST (F_v) TO STRUT / BRKT


$$F_v = 40 \#$$

CHECK ATR

$$\frac{1}{2} \phi \quad I = \frac{\pi r^4}{4} = 0.003 \text{ in}^4$$

$$F = \frac{\pi^2 EI}{L^2}$$

$$\frac{\pi^2 \times 29 \times 10^6 \text{ psi} (0.003 \text{ in}^4)}{(24 \text{ in})^2} \approx 1400 \# \quad \text{OK}$$



$$M \text{ @ BEAM} \Rightarrow 40 \# \times 24 \text{ in} = 960 \text{ in-lb}$$

$$T_k \approx \frac{M}{3.25} \approx 300 \#$$

$$W \frac{1}{2} \phi \text{ LAG BOLT} = 367 \#/\text{in}$$

$$Cd = 1.6 \therefore 587 \#/\text{in} \quad \text{USE } \frac{1}{2} \text{ in} \times 4 \text{ in LAG} \quad \text{OK}$$




5816 SW Gillcrest ct
Portland, OR 97221
Ph: 503.896.7712

City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic

REFERENCE




P2494 R-L THRU P2499 R-L



Vertical Channel	Uniform Design Load
Part No. Gauge	Lbs (kN)
P1000 12	300 (1.33)
P1100 14	250 (1.11)
P2000 16	200 (.89)


Safety Factor - 2½



Material : 12 Gauge Steel.
R - As shown; L - Opposite hand

Part Number	Stamped Ident. No.	"A" In (mm)	"B" In (mm)	Wt/100 pcs Lbs (kg)
P2494 R-L	121895 R-L	12 305	3 7/16 87	152 68.9
P2495 R-L	121896 R-L	14 356	3 15/16 100	173 78.5
P2496 R-L	121897 R-L	16 406	4 1/16 113	223 101.2
P2497 R-L	121898 R-L	18 457	4 15/16 125	266 120.7
P2498 R-L	121899 R-L	20 508	5 7/16 138	308 139.7
P2499 R-L	121900 R-L	22 559	5 5/16 151	355 161.0

P2500 R-L THRU P2503 R-L




Vertical Channel	Uniform Design Load
Part No. Gauge	Lbs (kN)
P1000 12	300 (1.33)
P1100 14	250 (1.11)
P2000 16	200 (.89)

Safety Factor - 2½

Material : 12 Gauge Steel.
R - As shown; L - Opposite hand

Part Number	Stamped Ident. No.	"A" In (mm)	"B" In (mm)	Wt/100 pcs Lbs (kg)
P2500 R-L	121901 R-L	24 610	6 7/16 164	400 181.4
P2501 R-L	121902 R-L	26 660	6 15/16 176	445 201.8
P2502 R-L	121903 R-L	28 711	7 1/16 189	493 223.6
P2503 R-L	121904 R-L	30 762	7 5/16 202	545 247.2

P2944, P2945, P2946, P2947




Part Number	"A" In (mm)	Wt/100 pcs Lbs (kg)	Uniform Load* Lbs (kN)
P2944	6 152	185 84	1200 5.34
P2945	12 305	293 133	600 2.67
P2946	18 457	401 182	400 1.78
P2947	24 610	509 231	300 1.33

Safety Factor 2½

* Mounted on 12 Ga. Channel

P2542 THRU P2546



Safety Factor - 2½

Part Number	"A" In (mm)	Wt/100 pcs Lbs (kg)	Vertical Channel Part No. Gauge	Uniform Design Load Lbs (kN)
P2542	12 305	502 228	P1000 12 P1100 14 P2000 16	2,000 (8.90) 1,400 (6.23) 1,000 (4.45)
P2543	18 457	692 314	P1000 12 P1100 14 P2000 16	1,300 (5.78) 900 (4.00) 650 (2.89)
P2544	24 610	882 400	P1000 12 P1100 14 P2000 16	1,000 (4.45) 700 (3.11) 500 (2.22)
P2545	30 762	1,072 486	P1000 12 P1100 14 P2000 16	800 (3.56) 560 (2.49) 400 (1.78)
P2546	36 914	1,262 572	P1000 12 P1100 14 P2000 16	650 (2.89) 450 (2.00) 320 (1.42)

Standard Dimensions for 1½" (41mm) width series channel fittings (Unless Otherwise Shown on Drawing)


Hole Diameter: 9/16" (14mm); Hole Spacing - From End: 13/16" (21mm); Hole Spacing - On Center: 1½" (48mm); Width: 1½" (41mm); Thickness: ¼" (6mm)

Note : When used for mechanical supports, load capacities of brackets and fittings should be in compliance with the American Standard Code for Pressure Piping.



P1843


ADJ. HINGE CONNECTION



Wt/100 pcs: 68 Lbs (30.8 kg)

P1354A


ADJ. HINGE CONNECTION




Wt/100 pcs: 89 Lbs (40.4 kg)

P1354

ADJ. HINGE CONNECTION




Wt/100 pcs: 109 Lbs (49.4 kg)



SPF® 100

SEISMIC PIVOT FITTINGS



Notes:

1. Design load is limited to slip capacity of a channel nut at hole "R".
2. Allowable loads have been determined by the manufacturers testing, analysis and technical specifications.
3. For retrofit application, engineer of record must verify.
4. Patented.
5. Square washer provided with fitting.
6. When a hanger rod is thru-bolted (in lieu of channel nut installation), higher transverse loads may be transmitted due to the higher allowed rod shear loads compared to channel nut slip values. This higher load may be used with verification through engineering calculations.

Part Number	Rod Size In (mm)	"R" - Hole Diameter In (mm)	Design Load Lbs (KN)
SPF 100-037	3/8 10	7/16 11	1,400 6.23
SPF 100-050	1/2 13	9/16 14	2,100 9.34
SPF 100-062	5/8 16	1 1/16 18	2,100 9.34
SPF 100-075	3/4 19	1 3/16 21	2,400 10.68


Safety Factor = 3.0

FINISH

Electro-galvanized (EG), conforming to ASTM B633 Type III SC1.

SPF® 200

ADJUSTABLE SEISMIC PIVOT FITTINGS



FINISH

Electro-galvanized (EG), conforming to ASTM B633 Type III SC1.

Part Number	Rod Size In (mm)	"R" - Hole Diameter In (mm)	Design Load Lbs (KN)
SPF 200-037	3/8 10	7/16 11	1,400 6.23
SPF 200-050	1/2 13	9/16 14	2,100 9.34
SPF 200-062	5/8 16	1 1/16 18	2,100 9.34
SPF 200-075	3/4 19	1 3/16 21	2,400 10.68

Safety Factor = 3.0

Notes:

1. Design load is limited to slip capacity of a channel nut at hole "R".
2. Allowable loads have been determined by the manufacturers testing, analysis and technical specifications at 45° from horizontal.
3. For retrofit application, engineer of record must verify.
4. Patented.
5. Square washer provided with fitting.
6. When a hanger rod is thru-bolted (in lieu of channel nut installation), higher transverse loads may be transmitted due to the higher allowed rod shear loads compared to channel nut slip values. This higher load may be used with verification through engineering calculations.

