



**NW PRECISION DESIGN**  
Architectural Design Consulting

Project Information

Permit Application: PRCTI20220017

Project Name: The UPS Store

Address: 2200 N Meridan

Occupancy: B

1. This form is not to the current 2018 version of the WSEC. Submit new forms to the current codes.  
**See revised form.**
2. All structural details for the installation of this roll-up gate must be incorporated into the plans and stamped by the Engineer of record not just as a part of this calculation documents.  
**See Sheet A4.1 for Detail**
3. The term unisex has taken on a new description in the 2018 IBC section 2902.2.2 WA. ST amendments. Page A0.1  
**See Sheet A0.1, 'PROJECT DATA/CODE SUMMARY' for revised description**
4. All this information would be required to be a part of this permit at this time except for the electrical portion that would need to go through the WA. ST department of L and I for permit. Page A0.1  
**See Sheet A0.1 for revised 'Deferred Submittal' list.**
5. This information is not correct. Page A0.1  
**See Sheet A0.1, revised**
6. The 11" X 17" pages that were also submitted would not be acceptable for this review and permit. All plan pages must be a min. of 24" X 36" like the first 4 pages of these plans. Index would need to reflect all pages in plan set. Page A0.1  
**All Sheets updated**
7. Must show how this one restroom meets all the requirements of sections 2902.2 and 2903 of the 2018 IBC and all the WA. ST. amendments to these sections. Page A4.1  
**See Sheet A4.1, Bathroom is 'Existing', no work to be done.**
8. Gate being installed must have signage to remain open during all business hours do to the required 2 exits. Page A4.1  
**See Sheets A4.1/A8.1 for added Signage.**



**NW PRECISION DESIGN**  
Architectural Design Consulting

9. The proposed lockers to be installed must comply with 2018 IBC section 1109.9, a minimum of 1 or 5% of these must meet accessibility requirements and be shown on the submitted plans. Page A4.1  
**See Sheet A4.1 for 'LOCKER/MAILBOX' Elevation, for minimum accessibility requirement.**
  
10. Proposed gate installation must have all engineering details shown on the plans for the additional framing and bracing. Those should match the details in the engineering packet completely. Page A4.1  
**See Sheet A4.1 for Structural Detail for Gate.**
  
11. Will need to show more exit signs directing people to the required exits per the 2018 IBC and tactile signage required too. Page A8.1  
**See Sheet A8.1, for added 'Directional' EXIT SIGN and added 'Tactical' EXIT SIGNAGE**
  
12. All plan pages must be a min. 24" X 36" and all pages must match. And not be done to design intent but actually what is being proposed for this tenant improvement. Page A0.0  
**All documents are part of the Construction Set.**

Thank you,

Darin Bouska  
NW Precision Design