



City of Puyallup
Engineering Division
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Comment Notice

Permit Application # E-21-0599

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Engineering Civil Review (Reviewed By: Mark Higginson, (253)841-5559, MHigginson@PuyallupWA.gov)

- ◆ Callout Vertical Datum[Plans; Sht 1/14 or GZT131

Engineering Traffic Review (Reviewed By: Bryan Roberts, (253)841-5542, broberts@PuyallupWA.gov)

- ◆ "Yield" sign is located only ~15ft from RR Crossing sign (#21). These signs must be spaced farther apart. (plans; sheet 9/14)
- ◆ Same as DP3 submittal provide WSDOT Signal Pole XYZ Wind loading calculation (IS-13) for pole G. Use standard plan J-26.10 to specify necessary foundation design. This information needs to be provided in plan set. (plans; sheet 12/14)
 - ◆ 7.99 ft
 - ◆ 1.50 ft
 - ◆ 6.00 ft
- ◆ RR ballast? Is there anything here to prevent people from walking over the edge of sidewalk? (plans; sheet 12/14)
- ◆ Edge of RR concrete pad(plans; sheet 12/14)
- ◆ Move truncated domes so they direct pedestrians directly across the tracks. Similar to other (plans; sheet 12/14)
- ◆ 1.5' x 6' Grouted Rip/RapHelp prevent pedestrians from walking out into 5th St NW while navigating sidewalk jog. (plans; sheet 12/14)

To resubmit, you must address all comments and complete the [resubmittal form](#). When you are ready to resubmit, you can do so using the customer portal, **by uploading a "new version" of the submittal requirement**. Please note, partial resubmittals will be deemed incomplete and returned.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center
(253) 864-4165 option 1
permitcenter@puyallupwa.gov