



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 08, 2022

Inspection Result: PASSED

Permit Number: B-21-0534

Property Address: 400 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: MCKINSTRY CO. 5005 3RD AVE S SEATTLE, WA 98124

To construct: RTU REPLACEMENT

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 provide final balance report

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684