



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Apr 11, 2022                      **Inspection Result:**     **FAILED**

**Permit Number:** PRCTI20220156

**Property Address:** 407 VALLEY AVE NE, PUYALLUP, WA 98372;

**Contractor:** FARRELL-MCKENNA CONSTRUCTION 17786 DES MOINES MEMORIAL  
DR    BURIEN, WA 98148 (206) 241-2600

**To construct:** Interior Unit Building Renovation - Meridian Pointe Apartments  
Building 'T' Units 108/208/308

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1    1 ; fix leak at auto wash box of clothes washing machine at unit 208 and call for reinspection.

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684