



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 14, 2022

Inspection Result: **FAILED**

Permit Number: E-21-0239

Property Address: 150 RIVER RD, PUYALLUP, WA 98371;

Contractor: WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW
GIG HARBOR, WA 98332

To construct: CIVIL~KORUM LINCOLN "VINTRINE" DEALERSHIP EXPANSION

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Need to clean up dirt around site CB's at low points. need to clean out dirt from gutter line around CB in cul-de-sac where FDC was installed. Need to clean out all CB socks. Need to protect disturbed edges from rain runoff on to asphalt.

Corrections:

Sincerely,

Jason Little
Engineering Tech IV



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

JLittle@PuyallupWA.gov

(253) 435-3636