



REVISION PR#2

Walmart
Puyallup, WA
WD Partners Job Number: WALGP0402

Date: March 18, 2022
To: Walmart Stores Inc
2001 SE 10th Street
Bentonville, AR 72716 USA
Attn : Kristen Dinger

The following information amends and supplements the original construction drawings and specifications and shall become part of the construction documents. All changes are identified on the drawings as Plan Revision, PR#2, with delta 2 symbol.

C1 : COVER SHEET

1. Deferred Submittals: Added to sheet

N2 : ENVELOPE COMPLIANCE

1. Added sheet to set

A8 : DOOR SCHEDULE, FINISHES AND DETAILS

1. Door Hardware Schedule: Added to sheet per AHJ comments
2. Door Schedule Notes: Revised Note #30 per CI#30793

OP1.2 : EXPANSION WALL SECTIONS AND DETAILS

1. Details 1-3: Revised R value of roof insulation to meet 2018 WSEC code requirements

S0 : GENERAL STRUCTURAL INFORMATION AND DETAILS

1. Updated Soils seismic criteria to match geotechnical report.
2. Updated Statement of Special inspections.

M2 : MECHANICAL DETAILS AND SCHEDULES

1. Detail 7: Added seismic detail to sheet per building comment.
2. Mechanical Ventilation Requirements: Added schedule to sheet showing O.A. provided exceeds the amount required per code.

P1 : ENLARGED PLUMBING PLAN, DETAILS AND SCHEDULE

1. Detail 1: Added trap primer detail callout and note to FD2 installation.
2. Detail 4: Added trap primer detail to sheet.
3. Roof Drain Calculations: Added gutter and downspout calculations to sheet.

E1.1 : ELECTRICAL COMPLIANCE REPORT

1. Revised energy compliance report.

E1.1A : ELECTRICAL COMPLIANCE REPORT

1. Added sheet E1.1A - ELECTRICAL COMPLIANCE REPORT.

T 614 634 7000
F 614 634 7777

7007 Discovery Boulevard
Dublin, OH 43017

wdpartners.com

E2 : PICKUP STORAGE POWER PLAN,NOTES AND DETAILS

1. Detail 2: Revised pickup storage power plan.
2. Feeder Schedule: Added feeder number 32.

E3 : ELECTRICAL ONE-LINE, DETAILS AND SCHEDULES

1. Added Voltage drop calculation.
2. Detail 1 : Revised fault current value.
3. Panel LPU : Revised circuit breaker size for circuit 14.
4. Panel LPU : Revised load in circuit number 1,3,5,2,4,6,16,18, and 20.

Please contact me with any questions you may have at 614.634.7219

Sincerely,

Ben Dariano
Planning & Permitting

END OF REVISION