



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Apr 29, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** E-21-0440

**Property Address:** 3303 8TH AVE SE ;

**Contractor:** MOUNTAIN CONSTRUCTION INC. 7457 S MADISON TACOMA, WA  
98409 Jeremy Patnoi 7457 S. Madison St. Tacoma, WA 98409

**To construct:** SEWER MODIFICATION AT THE EXISTING STEP BY STEP FACILITY ~ STEP  
BY STEP

\*confirm fees pls\*

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Trying to hydrotest fire line. They do not have a correct set up to burp the air. began at 8am! The entire fire line was finally hydro tested at 200psi for 2hrs. (PASSED) Parametrix was out to hydro test the PIV run at 200psi for 15min. (PASSED) Valley Water was out to take two purity samples. One for the FDC run and one for the PIV run.

**Corrections:**

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by a series of vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends to the right from the end of the signature.

Jason Little

Engineering Tech IV

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 435-3636