



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 29, 2022 **Inspection Result:** **PARTIAL PASS**

Permit Number: B-21-0256

Property Address: 3303 8TH AVE SE ;

Contractor: MOUNTAIN CONSTRUCTION INC. 7457 S MADISON TACOMA, WA
98409

To construct: TI ~ MODIFY BATHROOM; INCREASE KITCHEN; ADD STORAGE;
REMOVE CLASSROOM & OFFICE. ~ STEP BY STEP
BLDG/MECH/PLUMB

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide gas pipe plans from mechanical engineers of record. (provide test on gas pipe prior to frame cover approval.
- 2 ; provide new mechanical plan as built from mechanical engineer.
- 3 ; complete all anchor bolts as discussed with contractor.
- 4 ; complete install of HDU5;s with special inspection report for install of holdowns prior to frame approval.
- 2 1 ; provide gas pipe plan and test approval.
- 2 ; provide new mechanical as built plan approval from mechanical engineer.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive, flowing style.

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684