




File No: **S5479** CCN: **UUFX**
Service Center No: **0**
Expires: **12/03/2023**
Issued: **12/03/2018**

CENTRAL STATION - FIRE FIRE ALARM SYSTEM CERTIFICATE (NFPA 72)



THIS CERTIFIES that the *Alarm Service Company* is included by UL LLC in its Directory as qualified to use the *UL Listing Mark* in connection with the certificated *Alarm System*. This Certificate is the *Alarm Service Company's* representation that the *Alarm System* including all connecting wiring and equipment has been installed and will be maintained in compliance with requirements established by UL. This Certificate does not apply in any way to the installation of any additional signaling systems, such as; fire, smoke, waterflow, burglary, holdup, medical emergency, or otherwise, that may be connected to or installed along with the Certificated *Alarm System*. This Certificate does not apply in any way to the communication channel between the protected property and any facility that monitors signals from the protected property unless the use of a UL listed or Classified Alarm Transport Company is specified on the Certificate.

LIMITATION OF LIABILITY: UL LLC makes no representations or warranties, express or implied, that the Alarm System will in all cases prevent any loss by fire, smoke, water damage, burglary, hold-up or otherwise, or that the Alarm System will in all cases provide the protection for which it is installed or intended. By the Alarm Service Company providing this Certificate and the Protected Property acceptance of this Certificate, the Alarm Service Company and the Protected Property acknowledge and agree that UL does not assume or undertake to discharge any liability of the Alarm Service Company or any other party. UL is not an insurer and assumes no liability which may result directly or indirectly from inspection of the equipment, failure of the equipment, failure to conduct inspections, incorrect certification, nonconformity with requirements, failure to discover nonconformity with requirements, cancellation of the Certificate or withdrawal of the Alarm Service Company from inclusion in ULs Directory prior to the expiration date appearing on this Certificate.

OPERATIONAL REQUIREMENTS: The *Alarm Service Company* bears the responsibility for the correctness of the installation; maintenance of the system documentation; periodic system inspection and testing; maintaining and providing any necessary repairs. All operations and maintenance shall be conducted in the manner prescribed by the NFPA standard referenced. All required service is to be provided for in an appropriate contract. System documentation is defined to include any "As Built Drawings"; the records of any "Acceptance Testing"; and the records of all periodic system testing and maintenance.

SYSTEM DESCRIPTION: This system is installed and operated in accordance with standard NFPA 72, 1996 edition.

Area Covered: entire building
Authority Having Jurisdiction: City of Puyallup
Responding Fire Department: Puyallup Fire Department

SYSTEM DEVIATIONS FROM REFERENCED NFPA STANDARDS

none

Protected Property:

VAN LIEROP PROPERTY
302 33RD STREET
PUYALLUP, WA 98372

Alarm Service Company:

GUARDIAN SECURITY SYSTEMS
1743 1ST AVE S
SEATTLE WA 98134-1403

SN: FC112556647



File No: **S5479** CCN: **UUFX**
Service Center No: **0**
Expires: **12/03/2023**
Issued: **12/03/2018**
Entry No: **5580973** Version: **7**

CENTRAL STATION - FIRE FIRE ALARM SYSTEM CERTIFICATE DESCRIPTION FOR Certificate Serial No: FC112556647

| City of Puyallup Development & Permitting Services ISSUED PERMIT | | | |
|--|----------|-------------|--------------|
| Building | Planning | Engineering | Public Works |
| Fire | Traffic | | |

Protected Property:

VAN LIEROP PROPERTY
302 33RD STREET
PUYALLUP, WA 98372

Alarm Service Company:

GUARDIAN SECURITY SYSTEMS
1743 1ST AVE S
SEATTLE WA 98134-1403

System Description:

Area Covered: entire building
Authority Having Jurisdiction: City of Puyallup
Responding Fire Department: Puyallup Fire Department
Testing and Maintenance Contract date: 03/13/2018

SYSTEM DEVIATIONS FROM REFERENCED NFPA STANDARDS

none

Automatic Fire Detection and Alarm Service

Coverage is Total
4 - Smoke Detectors : 0 - Ionization 4 - Photoelectric

Alarm Notification and Annunciation Devices

1 - Bell
41 - Horns

Control and Transmitter Unit

Siemens, Cerberus Pro

Remote Monitoring

UL Listed Central Station
File: S5479, Service Center Number: 0
GUARDIAN SECURITY SYSTEMS
1743 1ST AVE S
SEATTLE WA 98134-1403

Alarm Retransmission to Fire Department

Public Telephone Network and 911 Emergency Services

Alarm Transmission Method: Radio Network/Transport (One-way)