

GARY K. MUNKELT & ASSOCIATES, LLC

1180 Welsh Road, Suite 190

North Wales, PA 19454

Phone: 215-855-8713 Fax: 215-855-8714

PROJECT: COSTCO WHOLESALE STORE #660 – PUYALLUP (REMODEL & ADDITIONAL RACKING THROUGHOUT THE STORE)

(STORAGE RACK BY RIDG-U-RAK)

LOCATION: 1201 39th AVENUE SW
PUYALLUP, WA 98373

PREPARED FOR: COSTCO WHOLESALE – ISSAQUAH, WA

TABLE OF CONTENTS

	SHEET
Reference Data – Scope of Work, Design Methods, Drawings, Loads & Seismic Parameters	1 - 4
3 – Level Storage Racks (Main Merchandise Area):	5 - 16
Storage Rack Beam Checks	5
Storage Rack Upright / Post Base Stability Checks	6 - 8
Storage Rack Upright / Post Longitudinal (Down Aisle) Seismic Checks	8 - 12
Storage Rack Upright / Post Transverse (Cross Aisle) Seismic Checks w /Anchorage	12 - 15
Storage Rack Bracing Checks	15 - 16
2 – Level Storage Racks (Merchandise Display):	16 - 23
Storage Rack Beam Checks	16
Storage Rack Upright / Post Base Stability Checks	16 - 18
Storage Rack Upright / Post Longitudinal (Down Aisle) Seismic Checks	18 - 21
Storage Rack Upright / Post Transverse (Cross Aisle) Seismic Checks w/Anchorage	21 - 23
Storage Rack Bracing Checks	23

Notice to Building Departments

If this calculation is submitted for building permit approval, it shall contain all sheets of calculations as listed in the table of contents and shall be accompanied by all drawings listed in Reference section on sheet 3, section 1.4 “Drawings”. All documents shall bear appropriate seals and signatures in ink of contrasting color.

REPRODUCTIONS OF SIGNED COPIES ARE INVALID

This report has been prepared in Collaboration with Peter S. Higgins & Associates

Date: 08/25/2021

GKM Job Number 2108127

Sheet #0 of #23

THE APPROVED CONSTRUCTION PLANS AND ALL ENGINEERING MUST BE POSTED ON THE JOB AT ALL INSPECTIONS IN A VISIBLE AND READILY ACCESSIBLE LOCATION.



THIS PAGE INTENTIONALLY LEFT BLANK

1 Reference Data:

1.1 Scope of Work and Codes:

This calculation reviews the installation of the storage racks for structural adequacy. The sealing of drawings is for the structural review of the storage racks only. Other information is not reviewed, nor approved. Note - The single level racking (5.0' high units) is exempt from the building permit (although it easily satisfies seismic criteria).

Code Requirements - IBC, ASCE/SEI 7, RMI/ANSI MH16.1, AISI/ANSI S100, and FEMA 460 are used for the design. (Exceeds 2018 IBC with WA Amendments as required - Seismic Requirements)

1.2 Project History:

This is a modification to a store reviewed by Peter S. Higgins & Associates per the following history:

Original Costco Store Review: June 2000 - (Higgins Job #04384)

Remodeled: January 2008 (Higgins Job #08359)

Cooler Addition: August 2013 (Higgins Job #10647)

Remodeled and Over Freezer Racks Added: May 2014 (Higgins Job #10970)

Meat Deli Cooler Remodeled: August 2015 (Higgins Job#11458)

Remodel / Additional Racks Sales Floor: June 2019 - (Higgins Job #13218 - GKM #190692)

Existing storage racks were installed under permits as required by the local authority, and remain qualified by the review and permit. Remodeling required, new racking can be substituted for existing racks, same rack material. New racking shown in revision clouds are reviewed in this report.

1.3 Design Methods:

1.3.1 Static Loads:

Per ANSI MH16.1, this review employs LRFD direct design methods which are the only unrestricted design method in AISC 360 & AISI S100. This report uses notional loads to determine second order displacements, and is found in AISC 360, Section C "Design For Stability" or AISI S100 Appendix 2.

1.3.2 Seismic Loads:

For seismic loads, FEMA 460 6.5.1 is employed (as permitted by ANSI MH16.1.2.6.2).

1.3.3 References:

In addition to the above documents, the reviewer is referred to the following references for assistance with these methods, and the connector values used in the design as required by both AISC 360 and FEMA 460.

1.3.3 References Continued:

General Design Methods:

Displacement Based Design for Storage Racks

Higgins, P,

ASCE/SEI Conference, Long Beach, CA (Invited paper)

ASCE/SEI Proceedings, 2007

Shake Table Results for Typical Racks:

Recent Shake Table Studies of Full Scale Storage Racks:

Filiatrault, A. , Wanitkorkul, A., Higgins, P.

ASCE/SEI Conference, Long Beach, CA (Invited paper, presented by Higgins)

ASCE/SEI Proceedings, 2007

Connector Values for Bolted Connector Racks:

Experimental Stiffness and Seismic Response of Pallet-Type Steel Storage Rack Connectors

Filiatrault, A. , Wanitkorkul, A., Higgins, P.,

ASCE J. Pract. Period Struct.Des. Constr. (11(3), 161-170 (2006)

Connector Values for Rivet Connector Racks:

Experimental Stiffness and Seismic Response of Pallet-Type Steel Storage Rack Tear Drop Connectors

Filiatrault, A. , Wanitkorkul, A., Higgins, P., Courtwright, J., ASCE J. Pract.

Period Struct. Des. Constr. (12(4), 210-215 (2007)

General Seismic Force Transverse Rack Behavior:

Experimental Seismic Response of Base Isolated Pallet-Type Storage Racks

Filiatrault, A. , Wanitkorkul, A., Higgins, P., Courtwright, J., Michael, A.

Earthquake Spectra 24:3 pp 617-639 August 2008.

Pallet Sliding Effects:

An Investigation - The Sliding of Pallets on Storage Racks Subject to Earthquake

Degee, H. , DeNoel, V.

FEM Research Project: RFS-PR-03114, Universite de Liege, 2006

These publications are widely available, and may be found in any large library, or easily borrowed from any leading University library.

1.4 Drawings:

1.4.1 By Gary K. Munkelt & Associates, LLC:

CW-10, RU-9

1.4.2 By Others:

Costco Wholesale #660 - Puyallup, WA

Proposed / Existing Floor Plan EX21 (Project #98-5080 - dated August 11, 2021)

1.5 Loads:


1.5.1 Vertical (Dead plus Live):

Load per pallet = 2.5 kips
Design beams for 25% impact

1.5.2 Impact Loads of Machine Loaded (Pallet / Selective) Racks:

Conservatively assume beams are simply supported UNO. Note: rack nomenclature is somewhat different than standard structural notation. Here L = Load on the beam (usually expressed in terms of a unit or pallet load). W = Width of the bay (or span of beam).

Take 25% impact of a single pallet as a UDL on 1/2 of span. There are two beams supporting each level (one front, one rear). Accordingly, each two pallet wide beam supports one pallet load on the full span, plus 1/8 of a pallet load on half of the span.



**GARY K MUNKELT AND ASSOCIATES ENGINEERING
CONSULTING STRUCTURAL ENGINEERS**

Project: Costco #660 - Puyallup
Date: 08/25/2021

GKM Job No. 2108127
Sheet 4 of 23

1.5.3 Seismic Continued:

ASCE 7 - section 15.5.3 per ANSI MH16.1, employing displacement based design per section 2.6.2.
The target displacement of the mass centroid per FEMA 460, section 6.5.1:

$$D = \frac{g S_{m1} T}{4 \pi^2 B}$$

The demands are to MCE levels which include the $I_e = 1.5$ factor for public warehouse stores.
Given:

$$\begin{aligned} S_{ms} = F_a S_s &= 2.90 \gg S_{ms \text{ actual}} = 1.52 \text{ - OKAY} \\ S_{m1} = F_v S_1 &= 1.50 \gg S_{m1 \text{ actual}} = 0.81 \text{ - OKAY} \end{aligned}$$

For default soils:

$$\begin{aligned} F_a &= 1.00 & S_s &\leq 2.90 \\ F_v &= 1.50 & S_1 &\leq 1.00 \end{aligned}$$

Note - The seismic coefficients for S_s & S_1 are based on high seismic areas. (Actual seismic Spectral Response Accelerations for this store located in Puyallup, WA are $S_s = 1.27$ $S_1 = 0.44$ per $S_{ms} = 1.52$; $S_{m1} = 0.81$ per ASCE 7 Hazards report $TL = 6$; $T_s = 0.54$; $1.5T_s = 0.80$)

B may be conservatively taken from the following table:

0.6 S_{ds}	Damping	B	0.6 $S_{ds} =$	1.16 g > 0.6g	B =	1.70
< 0.1g	5%	1.00				
0.2g	10%	1.20				
0.3g	15%	1.35				
0.4g	20%	1.50				
0.5g	25%	1.60				
>0.6g	30%	1.70				


Yielding:

$$D = 8.6 T$$

T may be determined by any rational method, but the formulations of

2 3 - Level Racks (Main Merchandise Area):

2.1 Components and Geometry:



W' = 105 "
a = 60 "
b = 60 "
c = 60 "

Beam Type - RB-S-500

H = 180 "
D = 34 "
l_y = 48 "
l_d = 54 " (Bottom two diagonals, 61" top diagonal)

Upright Type - UF-H-331

2.2 Check Beams:

2.2.1 Design Forces:


$$M \leq \frac{361 WL}{2560} =$$

51.8 inch kips factored

$$S_{min} < \frac{M}{\phi F_{ye}}$$

0.96 in³

2.2.2 Beam Properties:



RB-S-500

A = 5.00 in

t = 0.075 in

S_x = 1.40 in³

OK

I_x = 3.51 in⁴

OK


2.3 Check Posts (Dead plus Live Loads):

2.3.1 Vertical Load:

$$P < \frac{(\# \text{ of Levels})(L)}{2}$$

7.5 kips
10.5 kips factored

2.3.2 Second Order Effects:



Primary Notional Moment (base fixity assumption verified below)

$$M_{primary} = \eta P \frac{H}{2}$$

Deflection

$$\Delta = \eta P \left(\frac{H^3}{12EI_c} + \frac{H^2}{2K_\theta} \right)$$

Second Order Notional Moment

$$M_{P-\Delta} = \frac{P\Delta}{2} = \frac{\eta P^2}{2} \left(\frac{H^3}{12EI_c} + \frac{H^2}{2K_\theta} \right)$$

Define:

$$s = \frac{M_{P-\Delta}}{M_{primary}} = PH \left(\frac{H}{12EI_c} + \frac{1}{2K_\theta} \right)$$

To acceptable accuracy:

$$M_{notional} = M_{primary} \left(1 + \sum_{i=1}^{20} s^i \right) = \eta \frac{PH}{2} \left(1 + \sum_{i=1}^{20} s^i \right)$$

K_{theta} comprised of the beam end stiffness in series with the connector stiffness yielding:


$$K_{theta} = \left(\left(\frac{1}{K_{beam}} \right) + \left(\frac{1}{K_{conn}} \right) \right)^{-1}$$

With:

$$K_{beam} = \frac{6EI}{L_{beam}}$$

K_{conn} from tests or published literature

2.3.3 Post Properties (net section):



UF-H-33

d = 2.75 in
t = 0.125 in
As = 0.99 in²
Sx = 0.98 in³
rx = 1.19 in
Sy = 0.64 in³
ry = 0.95 in
Fy = 55.0 ksi

2.3.4 Post Demand, Capacity and Combined Stress Check:

Capacity

L_x = 60 in
L_y = 48 in
Kl/r_x = 50
Kl/r_y = 51
F_n = 44.8 ksi
φP_n = 37.7 kips
φM_{nx} = 48.5 inch kips
φM_{ny} = 31.7 inch kips

Stability

K_{conn} = 3000 in-kip / rad
I_{beam} = 3.51 in⁴ RB-S-500
L_{beam} = 102 in
K_{beam} = 5988 in-kip / rad
K_{theta} = 1999 in-kip / rad
s = 0.24

Demand

n = 0.005
P = 10.5 kips
H = 60 inch
M_{not} = 2.1 in-kip


2.3.4 Post Demand, Capacity and Combined Stress Check Continued:

Combined Stress = 0.32

2.4 Longitudinal Seismic:

2.4.1 Connection Properties:

The following are test results from Ridg-U-Rak for the beam end connector stiffness based on RMI MH16.1 specifications for testing of beam end loading:



Secant stiffness at 0.095 rad > 500 in-kips per radian
Maximum rotational capacity > 0.12 radians

2.4.2 Determine Period of Structure:

FEMA 460:

$$T_1 = 2\pi \sqrt{\frac{\sum_{i=1}^N W_{pi} h_{pi}^2}{g \left(N_c \left(\frac{k_c k_{bs}}{k_c + k_{bs}} \right) + N_b \left(\frac{k_b k_{cs}}{k_b + k_{cs}} \right) \right)}}$$

Nomenclature (used throughout)

Cd = displacement amplification factor from ASCE 7

DBE = Design Basis Earthquake

DBE/MCE = ratio of earthquake accelerations

Delta, tot Delta = horizontal displacement of a mass centroid, top mass centroid

Fa = site coefficient for short period per ASCE 7./NEHRP

Fv = site coefficient for 1 sec period per ASCE 7./NEHRP

g = acceleration due to gravity

Hcol = clear height of upright between levels - conservatively use spacing between beams

hpi = height of Wpi centroid above the base

I = structure importance factor

Ib = moment of inertia of beam

Ic = moment of inertia of column

K1 = constant as defined below

K2 = constant as defined below

kb = secant rotational stiffness of the base plate at the moment under consideration

kbe = end rotational stiffness of the beam (6EIb/L)

kbu = constant as defined below

kc = secant rotational stiffness of the connector at the moment under consideration

kce = end rotational stiffness of column (6EIc/Hcol) - FEMA 460 USES 4EIc/Hcol

kct = tangent rotational stiffness of the connector at the moment under consideration

ku = constant as defined below

L = bay width

Mc = moment in beam end connector

MCE = Maximum considered earthquake

Nb = number of base plates in the run of rack

2.4.2 Determine Period of Structure Continued:

N_c = number of beam end connectors in the run of rack

R = response reduction factor from RMI

S_1 = Site seismic coefficient from ASCE7/RMI

S_{d1} = Design spectral response acceleration parameter = $S_{m1}(DBE/MCE)$

S_{ds} = Design spectral response acceleration parameter = $S_{ms}(DBE/MCE)$

S_{m1} = Site seismic coefficient (= $F_v S_1$)

S_{ms} = Site seismic coefficient (= $F_a S_s$)

S_s = Site seismic coefficient from ASCE7/RMI

T = structure period as computed at right

V_b = base shear for the entire storage rack as computed below

W = Total rack weight

W_{pi} = Weight at a given position in a run of rack

Defined Expressions

$$K_1 = N_c + N_b \left(\frac{k_b k_{ca}}{k_c k_{ba}} \right) \left(\frac{k_c + k_{ba}}{k_b + k_{ca}} \right)$$

$$K_2 = N_c k_{bu} + N_b k_u$$

$$k_{bu} = \frac{k_c k_{ba}}{k_a + k_{ba}}$$

$$k_u = \frac{k_b k_{ca}}{k_b + k_{ca}}$$

Substitution of these expressions into the period equation above yields:

$$T_1 = 2\pi \sqrt{\frac{\sum_{i=1}^N W_{pi} h_{pi}^2}{g (N_c k_{bu} + N_b k_u)}}$$

This formulation is a general solution for racks with a variable importance factor. The $I_e = 1.5$ is included in the displacement demand computed above. [While present in the generalize formulation nomenclature, The ASCE 7 C_d amplification factors are not used for the analysis].

The solution is an iterative procedure where the connector stiffness is converged with the rotational angle. For this structure, the upper bound period displacement demand does not exceed the capacity of the connector, therefore the following will be used to calculate the period in the longitudinal (down aisle) direction. The connector properties are shown in the above testing chart for a combined strength (Moment vs. Rotation) per pair of connectors.

**GARY K MUNKELT AND ASSOCIATES ENGINEERING
CONSULTING STRUCTURAL ENGINEERS**

Project: Costco #660 - Puyallup
Date:08/25/2021

GKM Job No. 2108127
Sheet 11 of 23

2.4.2 Determine Period of Structure Continued:

The typical row in a Costco is minimum 8 bays long. For this configuration:

No. Bays	8			g	386	in ² sec ²
No. Level	3			E	29000	ksi
L	108	inches C/C		Nc	48	
W	5	kips / level		Nb	9	
Ib	3.5	in ⁴ (RB-S-500)		Kbe	5639	
Ic	1.4	in ⁴		Kce	4060	
Kc	500	in-kips/rad from above		Kbu	459	
Kb	3000	in-kips/rad		Ku	1725	
				K1	81.8	
				K2	37572	

For a rack with a constant load per level and spacing between beams:

Level	Wpi	hpi	Wpi*hpi	Wpi*hpi ²
1	20	84	1680	141120
2	20	144	2880	414720
3	20	204	4080	832320
Sum or Max	60	204	8640	1388160

Yields T = 1.94 sec

2.4.3 Displacement / Rotational Demand:

First order displacement demand:

D = 8.6T = 16.8 inches

Second order effects:

$$D_{tot} = D(1 + \alpha)$$

Where:

$$\alpha = \frac{\sum_{i=1}^{N_L} W_{pi} h_{pi} \left(\frac{k_c + k_{be}}{k_c k_{be}} \right)}{\left(N_c + N_b \left(\frac{k_b k_{ce}}{k_c k_{be}} \right) \left(\frac{k_c + k_{be}}{k_b + k_{ce}} \right) \right)} = 0.23$$

Yielding:

D_{tot} = 20.6 inches

2.4.3 Displacement / Rotational Demand Continued:

Rotational Demand:

$$\theta_{\max} = D_{\text{tot}} / h_{\text{pi}} \text{ max.} = 0.10 \text{ radian}$$

2.4.4 Connector Capacity:

The stiffness corresponds to the rotational demand, and is within the capacity of the connector.

NOTE: Racks are acceptable under longitudinal, down aisle direction under seismic consideration:

2.5 Transverse Seismic:

Machine Loaded Racks - 34" minimum upright depth governs by inspection.

2.5.1 Determine Period:

The upright / posts are braced using horizontal & diagonal channels in the transverse direction, and may be reasonably considered as a cantilever off the floor slab.

2.5.1 Determine Period in Transverse Direction Continued:

Determine Period - Ref. Roark's Formulas for Stress & Strain, 7th ed., Table 16.7, Case 3b:

$$T = \frac{2\pi}{3.52} \sqrt{\frac{Wl^3}{EIg}}$$

For:

$$D = 34 \text{ in (depth of upright)}$$

$$I < 0.8[2(D/2)^2 As] = 458 \text{ in}^4$$

$$W = 15.0 \text{ kips (bay load)}$$

$$l = 180 \text{ in (top beam level)}$$

$$T = 0.23 \text{ sec}$$

2.5.2 Displacement Demand:

Second order deflections are clearly negligible, yielding

$$D_{\text{tot}} = 2.0 \text{ inches}$$

2.5.3 Displacement Capacity:


While the uprights and beams will deflect under lateral load, this displacement can be easily accommodated by pallet sliding. Movement of the pallets may included in the displacement capacity per ANSI MH16.1 section 2.6.2 Commentary.

Per the above reference, Degee paper, cited above, the maximum (and very rare) pallet coefficient of friction on the steel is less than 0.6. For $\mu / \alpha < 0.4$, the pallets do not stick. Conservatively taking $\alpha = 0.6Ss = 1.7$, this ratio will not exceed $0.6 / 1.7 = 0.36 < 0.40$, so the pallets will not stick, and the dynamic coefficient of friction may be used.

2.5.4 Stability:

ANSI MH16.1 and FEMA 460 are silent on the shear demand to the frame when pallet movement only is used to satisfy the displacement demand. Since sliding forces cannot exceed the coefficient of friction on the dynamically active fraction of the load. The COF for wood on steel (Plastic pallets have a lower value) is typically 0.2 - 0.3. Conservatively use 0.3 to develop base shear.

$$V = 0.3(15.0)(2/3) = 3.0 \text{ kips (Load per Bay) This will further conservatively be applied in the triangular force distribution on the upright.}$$



$$P_{eq} = \frac{Vh'}{D}$$

$h' =$	160 inches
$OTM = Vh' =$	480 inch kips
$RM = WD/2 =$	255 inch kips ($W = 15.0 \text{ kips / bay}$)
$\text{Net OTM} =$	225 inch kips
$P_{eq} = OTM / D =$	14.1 kips

Note: Bracing shown is schematic - see section 2.1 for actual geometry.

2.5.5 Post Capacity:

$$P + P_{eq} = 21.6 \text{ kips} < \phi P_n = 37.7 \text{ kips} \quad \underline{\text{OK}}$$

2.5.6 Stability:

$$T_{anchors} = \text{Net OTM} / D = 6.6 \text{ kips}$$

**GARY K MUNKELT AND ASSOCIATES ENGINEERING
CONSULTING STRUCTURAL ENGINEERS**

Project: Costco #660 - Puyallup
Date:08/25/2021

GKM Job No. 2108127
Sheet 14 of 23

2.5.6 Stability Continued:

NOTE:

Based on above analysis, the seismic ground motion coefficients for Puyallup, WA are much less than noted above, therefore anchoring is acceptable for Puyallup, WA.

2.5.7 Anchorage:

Steel strength of anchor in tension will not govern:

Concrete Anchor Breakout Strength per ACI 318, Chapter 17:

Concrete Pull-out does not govern on external threaded screw anchors:

Units: pounds, inches UNO

Analysis based on no edge distance issues:

Symbol	Units	Description
Anc	in ²	Breakout area of anchor group
Anco	in ²	Breakout area of one anchor
h_{ef}	inches	Minimum effective embedment
f'_c	psi	Concrete strength used per RMI minimum or project site concrete strength
δ_a	none	Modification for light weight concrete
$\phi_{sa}nV_{saeq}$	Lbs.	Total Shear resistance of the 1/2 steel anchors
$\phi_{cb}V_{cbg}$	Lbs.	Shear Capacity for the (2) 1/2 steel anchors (no edge distance issues)
Basic f'_c	psi	Basic Concrete Strength after 28 days for pullout
Category	none	Per ACI 318 Section 17.3.3
Cone Cap	Lbs. none	Breakout capacity of concrete for bolt group ACI 318 - Section 17.4.2.2
K_{Cr} & K_{Uncr}	none	
N_b	Lbs.	ACI 318 - Section 17.4.2.2
$N_{p,cr}$	Lbs.	Report pullout capacity in cracked concrete
$N_{p,uncr}$	Lbs.	Report pullout capacity in uncracked concrete
ϕ_i	none	Combined strength reduction under seismic per ACI 318 - 17.2.3.4.4 & (0.75*0.65) = 0.49
$\phi_i N_{cbg}$	Lbs.	Capacity of bolt group (bolts or concrete) ACI 318 - Section 17.4.2.1
S1	inches	Spacing between two anchors in one row
S2	inches	Spacing between rows of two anchors

2.5.7 Anchorage Continued:

$\psi_{c,N}$	none	Per ACI 318 - Section 17.4.2.6	(post installed, $K_{cr} = 17$)
$\psi_{ec,N}$	none	Per ACI 318 - Section 17.4.2.4	(concentric load)
$\psi_{ed,N}$	none	Per ACI 318 - Section 17.4.2.5	(distance form edges)
$\delta_a =$	1.0	Modification for light weight concrete	
Variables		Basis $f'_c = 2500$	
Concrete		Anchors 1/2" diameter - Hilti KH-EZ Screw Anchors referenced	
$f'_c =$	3000	$N_{p,uncr} = N/A$ With screw type anchors	
Computed		$N_{p,cr} = N/A$ With screw type anchors	
Anco =	144	Category	1
Anc =	216	$K_{uncr} =$	24
Nb =	7449	$K_{cr} =$	17
$\psi_{c,N} =$	1.4	Phi =	0.49
$\psi_{ec,N} =$	1.0	$h_{ef} =$	4.0 (Conservatively use 4") $h_{nom} = 5.0"$
$\psi_{ed,N}$	1	S1 =	6.0
ϕN_{cbg}	7626	S2 =	0.0

Based on the above analysis, maximum base shear can be resisted by the available shear capacity for the anchor group (2 anchors per group / plate).


** For High Seismic Areas use 1/2" diameter ICC approved external thread (Screw Anchors) with minimum effective embedment of 4" as shown above (5" minimum nominal embedment)

2.5.8 Brace:

2.5.8.1 Design Forces:

$P_{br} \leq 5.7$ kips (Bottom two diagonals)

2.5.8.2 Brace Capacity:




$A_{net} = 0.32$ in²
 $r_{min} = 0.46$ in
 $\phi = 0.85$ (AISI - Compression elements)
 $k = 0.80$
 $t = 14ga$

2.5.8.2 Brace Capacity Continued:

L	$\frac{kl}{r}$	F_n	ϕP_n	
(in)	r	(ksi)	(kips)	
54	95	26.6	7.2	<u>OK</u>

3 2 - Level Racks (Merchandise Display):

3.1 Components and Geometry:



W' = 105 "
a - b = 96 " max

Beam Type - **RB-S-500**

H = 180 " (120" for the 2 Level Racks with same loading)
D = 34 "
l_y = 48 "
l_d = 54 " (Bottom two diagonals, 61" top diagonal)
Upright Type - **UF-H-33I**

3.2 Check Beams:

OK per section 2.2.

3.3 Check Posts (Dead plus Live Loads):

3.3.1 Vertical Load:


$$P < \frac{(\# \text{ of Levels})(L)}{2} =$$

5.0 kips
7.0 kips factored

3.3.2 Second Order Effects:

Refer to section 2.3.2 for derivation.

3.3.3 Post Properties (net section):



UF-H-33

d =	2.75 in
t =	0.125 in
As =	0.99 in ²
Sx =	0.98 in ³
rx =	1.19 in
Sy =	0.64 in ³
ry =	0.95 in
Fy =	55 ksi

3.3.4 Post Demand, Capacity and Combined Stress Check:

Capacity

$L_x =$	96 in
$L_y =$	48 in
$KI/r_x =$	81
$KI/r_y =$	51
$F_n =$	32.6 ksi
$\phi P_n =$	27.4 kips
$\phi M_{nx} =$	48.5 inch kips
$\phi M_{ny} =$	31.7 inch kips

Stability

$K_{conn} =$	3000 in-kip / rad
$I_{beam} =$	3.51 in ⁴ RB-S-500
$L_{beam} =$	102 in
$K_{beam} =$	5988 in-kip / rad
$K_{theta} =$	1999 in-kip / rad
s =	0.30

Demand

n =	0.005
P =	7.0 kips

3.3.4 Post Demand, Capacity and Combined Stress Check Continued:

Demand Continued

H = 96 inch
 M_{not} = 2.31 in-kip

Combined Stress = 0.30


3.4 Longitudinal Seismic:

3.4.1 Connection Properties:

The following are test results from Ridg-U-Rak for the beam end connector stiffness based on RMI MH16.1 specifications for testing of beam end loading:

Combined Strength - Moment vs Rotation

—RR-410-300-126-4B



Secant stiffness at 0.095 rad > 500 in-kips per radian
Maximum rotational capacity > 0.12 radians

3.4.1 Connection Properties Continued:

Note - For the Merchandise Display, 2 Level Racks & 3 Level Racks, the RB-S-500 beams have the same beam end connectors, therefore have the same Combined Strength - Moment vs Rotation chart as shown on the following page:

For the nomenclature for determining the period of the structure refer to section 2.4.2:

3.4.2 Determine Period of Structure:

FEMA 460:

$$T_1 = 2\pi \sqrt{\frac{\sum_{i=1}^N W_{pi} h_{pi}^2}{g \left(N_c \left(\frac{k_c k_{be}}{k_c + k_{be}} \right) + N_b \left(\frac{k_b k_{ce}}{k_b + k_{ce}} \right) \right)}}$$

$$K1 = N_c + N_b \left(\frac{k_b k_{ce}}{k_c k_{be}} \right) \left(\frac{k_c + k_{be}}{k_b + k_{ce}} \right)$$

$$K2 = N_c k_{bu} + N_b k_{bu}$$

$$k_{bu} = \frac{k_c k_{be}}{k_c + k_{be}}$$

$$k_u = \frac{k_b k_{ce}}{k_b + k_{ce}}$$

Substitution of these expressions into the period equation above yields:

$$T_1 = 2\pi \sqrt{\frac{\sum_{i=1}^N W_{pi} h_{pi}^2}{g (N_c k_{bu} + N_b k_u)}}$$

This formulation is a general solution for racks with a variable importance factor. The $I_e = 1.5$ is included in the displacement demand computed above. [While present in the generalize formulation nomenclature, The ASCE 7 C_d amplification factors are not used for the analysis].

The solution is an iterative procedure where the connector stiffness is converged with the rotational angle. For this structure, the upper bound period displacement demand does not exceed the capacity of the connector, therefore the following will be used to calculate the period in the longitudinal (down aisle) direction. The connector properties are shown in the above testing chart for a combined strength (Moment vs. Rotation) per pair of connectors.

**GARY K MUNKELT AND ASSOCIATES ENGINEERING
CONSULTING STRUCTURAL ENGINEERS**

Project: Costco #660 - Puyallup
Date:08/25/2021

GKM Job No. 2108127
Sheet 20 of 23

3.4.2 Determine Period of Structure Continued:

The typical row in a Costco is minimum 8 bays long. For this configuration:

No. Bays	8		g	386	in ² sec ²
No. Level	2		E	29000	ksi
L	108	inches C/C	Nc	32	
W	5	kips / level	Nb	9	
Ib	3.5	in ⁴ (RB-S-500)	Kbe	5639	
Ic	1.4	in ⁴	Kce	2538	
Kc	500	in-kips/rad from above	Kbu	459	
Kb	3000	in-kips/rad	Ku	1375	
			K1	58.9	
			K2	27069.3	

For a rack with a constant load per level and spacing between beams:

Level	Wpi	hpi	Wpi*hpi	Wpi*hpi ²
1	20	134	2680	359120
2	20	204	4080	832320
Sum or Max	40	204	6760	1191440

Yields T = 2.12 sec

3.4.3 Displacement / Rotational Demand:

First order displacement demand:

D = 8.6T = 18.3 inches

Second order effects:

$D_{tot} = D(1 + \alpha)$

Where:

$$\alpha = \frac{\sum_{i=1}^{N_L} W_{pi} h_{pi} \left(\frac{k_c + k_{be}}{k_c k_{be}} \right)}{\left(N_c + N_b \left(\frac{k_b k_{ce}}{k_c k_{be}} \right) \left(\frac{k_c + k_{be}}{k_b + k_{ce}} \right) \right)} = 0.25$$

Yielding:

D_{tot} = 22.9 inches

Rotational Demand:

θ_{max} = D_{tot} / h_{pi} max. = 0.11 radian

3.4.4 Connector Capacity:

The stiffness corresponds to the rotational demand, and is within the capacity of the connector.

NOTE: Racks are acceptable under longitudinal, down aisle direction under seismic consideration:

3.5 Transverse Seismic:

Machine Loaded Racks - 34" minimum upright depth governs by inspection.

3.5.1 Determine Period:

The upright / posts are braced using horizontal & diagonal channels in the transverse direction, and may be reasonably considered as a cantilever off the floor slab.

Determine Period - Ref. Roark's Formulas for Stress & Strain, 7th ed., Table 16.7, Case 3b:

$$T = \frac{2\pi}{3.52} \sqrt{\frac{Wl^3}{EIg}}$$

For:

$$D = 34 \text{ in (depth of upright)}$$

$$I < 0.8[2(D/2)^2 A_s] = 458 \text{ in}^4 \quad (\text{moment of inertia})$$

$$W = 10.0 \text{ kips (bay load)}$$

$$l = H = 180 \text{ in (top beam level)}$$

$$T = 0.19 \text{ sec}$$

3.5.2 Displacement Demand:

Second order deflections are clearly negligible, yielding

$$D_{\text{tot}} = 1.6 \text{ inches}$$

3.5.3 Displacement Capacity:

While the uprights and beams will deflect under lateral load, this displacement can be easily accommodated by pallet sliding. Movement of the pallets may included in the displacement capacity per ANSI MH16.1 section 2.6.2 Commentary.

3.5.3 Displacement Capacity:


Per the above reference Degee paper cited above, the maximum (and very rare) pallet coefficient of friction on the steel is less than 0.6. For $\mu / \alpha < 0.4$, the pallets do not stick. Conservatively taking $\alpha = 0.6$ and $S_s = 1.7$, this ratio will not exceed $0.6 / 1.7 = 0.36 < 0.40$, so the pallets will not stick, and the dynamic coefficient of friction may be used.

3.5.4 Stability:

ANSI MH16.1 and FEMA 460 are silent on the shear demand to the frame when pallet movement only is used to satisfy the displacement demand. Since sliding forces cannot exceed the coefficient of friction on the dynamically active fraction of the load. The COF for wood on steel (Plastic pallets have a lower value) is typically 0.2 - 0.3. Conservatively use 0.3 to develop base shear.

$$V = 0.3(10.0)(2/3) = 2.0 \text{ kips (10.0 kips per Bay) This will further conservatively be applied in the triangular force distribution on the upright.}$$

3.5.4 Stability Continued:



$$P_{eq} = \frac{Vh'}{D}$$

Use h' = Uses top beam level of rack

$$h' = 180 \text{ inches}$$

$$OTM = Vh' = 360 \text{ inch kips}$$

$$RM = WD/2 = 170 \text{ inch kips (W = 10.0 kips / bay)}$$

$$\text{Net OTM} = 190 \text{ inch kips}$$

$$P_{eq} = OTM / D = 10.6 \text{ kips}$$

Note: Bracing shown is schematic - see section 3.1 for actual geometry.

3.5.5 Post Capacity:

$$P + P_{eq} = 15.6 \text{ kips} < \phi P_n = 27.4 \text{ kips} \quad \text{OK}$$

3.5.6 Stability:

$$T_{bolt} = \text{Net OTM} / D = 5.6 \text{ kips}$$

3.5.6 Stability Continued:

NOTE:

Based on above analysis, the seismic ground motion coefficients for Puyallup, WA are much less than noted above, therefore anchoring is acceptable for Puyallup, WA.

3.5.7 Anchorage:

Refer to section 2.5.7 for calculations for determining the available capacity of the anchors. Based on the above uplift force use minimum 1/2" diameter ICC approved external thread screw anchors with a minimum embedment of 4.0" (5.0" nominal embedment) into concrete slab for above high seismic zones.


3.5.8 Brace:

Horizontal & diagonal braces are the same section, therefore diagonal brace will govern design.

3.5.8.1 Design Forces:

$$P_{br} \leq 3.8 \text{ kips}$$

2.5.8.2 Brace Capacity:



$$A_{net} = 0.32 \text{ in}^2$$

$$r_{min} = 0.46 \text{ in}$$

$$\phi = 0.85 \text{ (AISI - Compression)}$$

$$k = 0.80$$

$$t = 14ga$$

L	$\frac{kl}{r}$	F_n	ϕP_n	
(in)	r	(ksi)	(kips)	
54	95	26.6	7.2	<u>OK</u>