

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	May 02, 2022	Inspection Result:	FAILED
Permit Number: Property Address:	B-21-0583 507 31ST AVE SW, PUYA	LLUP, WA 98373;	
		T PL NE REDMOND, W	A 98053 (425) 260-6955
To construct:	TI COMBINE (2) SUITES	INTO 1 OFFICE ~ STEWA	RT TITLE

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1 ; complete install of expansion tank.
2 ; provide Dbl. check at hard lined coffee maker as required on last plumbing final inspection dated 4/28/2022.

Sincerely,

King

Shannon King Building Inspector 2 ShannonK@PuyallupWA.gov (253) 840-6684