



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Apr 25, 2022                      **Inspection Result:**     **FAILED**

**Permit Number:** B-21-0256

**Property Address:** 3303 8TH AVE SE     ;

**Contractor:** MOUNTAIN CONSTRUCTION INC. 7457 S MADISON TACOMA, WA  
98409

**To construct:** TI ~ MODIFY BATHROOM; INCREASE KITCHEN; ADD STORAGE;  
REMOVE CLASSROOM & OFFICE. ~ STEP BY STEP  
BLDG/MECH/PLUMB

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** INSP COMBINATION FRAME AND ROU - No Comments

**Corrections:**

- 1    1 ; provide gas pipe plans from mechanical engineers of record. ( provide test on gas pipe prior to frame cover approval.
- 2 ; provide new mechanical plan as built from mechanical engineer.
- 3 ; complete all anchor bolts as discussed with contractor.
- 4 ; complete install of HDU5;s with special inspection report for install of holdowns prior to frame approval.

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive, flowing style.

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684