City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 04, 2022 Inspection Result: FAILED

Permit Number: E-21-0440

Property Address: 3303 8TH AVE SE

Contractor: MOUNTAIN CONSTRUCTION INC. 7457 S MADISON TACOMA, WA

98409 Jeremy Patnoi 7457 S. Madison St. Tacoma, WA 98409

To construct: SEWER MODIFICATION AT THE EXISTING STEP BY STEP FACILITY ~ STEP

BY STEP

confirm fees pls

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: RW Scott tied the fire line to the main. Parametrix is on site. They flushed the fire line 3 times at 15min. each. The bags had debris in each flush.

Note: I sent an email to the owners, parametrix, and the city's fire inspector asking them to install screen with another flush to verify no debris will clog the fire heads.

<u> </u>	rre	:	_	
\cdot	rra	CTI	n	uc.
\mathbf{v}	'I I C	G L I	v	ıı.


Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org



Jason Little Engineering Tech IV JLittle@PuyallupWA.gov (253) 435-3636